Burnett, James

From: Bayliss, Gillian
Sent: Thursday, May 05, 2016 1:00 PM
To: Swithenbank, Arne; Planning (SMDC)
Subject: SMD/2016/0260

Overton Hall Barns, Biddulph

Proposal to install a 1.2m powder-coated metal flue pipe within the roof of this Grade II Listed Building. The pipe will by 150mm diameter and project 100mm above the ridge. The building has been converted to a dwelling and this addition will not detract from the agricultural character or historic interest of the building. No objections. To be reported to CLP 17th May 2016.

Thanks

Gill Bayliss
Senior Conservation Officer
Staffordshire Moorlands District Council & High Peak Borough Council
Email: gillian.bayliss@staffsmoorlands.gov.uk
Tel: 01538 395576
Mobile: 07976 753886
Please note that my working days are Monday-Thursday

Do you really need to print out this Email? Be green - keep it on the screen.

This transmission is intended for the named addressee(s) only and may contain sensitive or protectively marked material up to RESTRICTED and should be handled accordingly. Unless you are the named addressee (or authorised to receive it for the addressee) you may not copy or use it, or disclose it to anyone else. If you have received this transmission in error please notify the sender immediately. All GCSX traffic may be subject to recording and/or monitoring in accordance with relevant legislation.

If this has come to you in error, please notify the sender immediately and delete this email from your system. The Council may be required to disclose this email or any response to it under the Freedom of Information Act 2000

http://www.staffsmoorlands.gov.uk