Walker, Hazel

From: Ollerenshaw, Mark
Sent: 02 August 2016 09:23
To: Planning (SMDC)
Subject: FW: SMD/2016/0353 - Shrubbery Cottage, Cheadle Road, Cheddleton, ST13 7BW
Attachments: SMDC biomass_boiler_info_form.doc

Environmental Health comments on above application.

From: Colgan, Denis
Sent: 02 August 2016 09:17
To: Ollerenshaw, Mark
Subject: RE: SMD/2016/0353 - Shrubbery Cottage, Cheadle Road, Cheddleton, ST13 7BW

HelloMark,

There are two concerns –

1. Air pollution from bio-mass boiler. Form attached, this form is required in order that we can understand potential impacts.
2. Noise from operation of boiler. We would advise an operating condition requiring the boiler not to exceed background noise levels when operating. See below -

Condition -
The machinery, plant or equipment including installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated that the noise generated by the operation of the machinery shall not increase the background noise levels during day time expressed as LA90 [1hour] (day time 07:00-23:00 hours) and/or (b) LA90 [15 mins] during night time (night time 23:00-07:00 hours) at any adjoining noise sensitive locations or premises in separate occupation above that prevailing when the machinery is not operating. Noise measurements for the purpose of this condition shall be pursuant to BS 4142:2014. The details and location of any plant or machinery to be installed under this permission should be submitted to and approved of in writing by the Local Planning Authority.

Reason:- To safeguard the amenity of local residents and that of the surrounding area from noise disturbance.

Thank You,

Denis

Mr Denis Colgan
Pollution Officer (Specialist)
Environmental Health
Staffordshire Moorlands District Council / High Peak Borough Council
01538 395400 ext 4404 or 07713189069

Do you really need to print out this Email? Be green - keep it on the screen.

This transmission is intended for the named addressee(s) only and may contain sensitive or protectively marked material up to RESTRICTED and should be handled accordingly. Unless you are the named addressee (or authorised to receive it for the addressee) you may not copy or use it, or disclose it to anyone else. If you have received this transmission in error please notify the sender immediately. All GCSX traffic may be subject to recording and/or monitoring in accordance with relevant legislation.

If this has come to you in error, please notify the sender immediately and delete this email from your system. The Council may be required to disclose this email or any response to it under the Freedom of Information Act 2000

http://www.staffsmoorlands.gov.uk