

Site Plan **1:1250**

New Paladin Fencing
Install FH Brundle 'Twilfix' or similar 60x60mm PPC galvanised steel posts at 2975mm centres (or as manufacturer's recommendations) with maximum 3025mm wide FH Brundle or similar 'Paladin Classic' flush edged panels. Fix 3200mm posts for 2400mm high fencing and perform cutting for any make-up panels on-site, making good using a zinc etch primer paint and top coat of Cromadex 222 polyurethane repair paint. Use proprietry corner posts for standard 90 degree internal and external corners, with obtuse corners formed using proprietry intermediate posts.

Where installing on sloping ground, ensure that a 100mm step between panels is not exceeded, altering post centres and panel widths to achieve this, and burying base of fence where necessary.

Foundations are to be no leaner than 1 part cement to 10 parts 20mm nominal size graded aggregates, thoroughly compacted prior to initial set. Foundation sizes indicated are for normal ground and may require modification to suit prevailing ground conditions on site.

Provide new 2400mm high paladin mesh gate to match size and style of new boundary fencing. Provide and include for key fob access control system.



Panel Fixing Detail - NTS



Straigh Panel Post Detail - NTS



Angled Panel Post Detail - NTS



Right Angled Post Detail - NTS



Typical 2400 High Fence Elevation **1:20**



Typical 2400 High Gate Elevation **1:20**

RevID	Issue Date	Comment	Modified By	Checked By

Drawing Status

wood goldstraw yorath
ARCHITECTS QUANTITY SURVEYORS CDM CO-ORDINATORS
Churchill House, Regent Road, Stoke on Trent, ST1 3RH.
Tel: 01782 208000 Fax: 01782 208712 E-mail: info@woodgoldstraw.co.uk
http://www.woodgoldstraw.co.uk/

Client.
Churnet View Middle School
Leek

Project.
Safeguarding Works 2016

Scale	Issue Date
1:1250, 1:20	11/11/2016
Sheet Size: A1	Drawn: L.Adams
	Checked

Title.
New Boundary Fencing - Working Drawing

Drawing Number	Revison ID
4381-02-05	

CAD file path:
X:\1 A CAPPER'S TEAM\6 SCHOOL OTHER\LEEK - CHURNET VIEW MIDDLE SCHOOL\4381-02 - Fire Doors and Fencing CF 17-18\4381-02 Existing.pln

Copyright. Wood Goldstraw & Yorath.
Contractors are to check all dimensions on site and refer any discrepancies to the Architects immediately. Do not scale from this drawing.