



ELEVATION W01 Scale 1:10




Window set back 100mm from external face of brickwork..

SECTION D - CILL DETAIL Scale 1:2

EX 100mmx50mm Hardwood Window head.


EX 50mmx50mm Hardwood casement top rail.

Histoglass 12mm wide double glazed unit with aluminium spacer bar.



SECTION A - HEAD DETAIL Scale 1:2

EX 44mmx20mm Hardwood glazing Bar.




SECTION B - GLAZING BAR Scale 1:2

Histoglass 12mm wide double glazed unit with aluminium spacer bar.

EX 63mmx50mm Hardwood casement base rail.

EX 100mmx75mm Hardwood window cill.



SECTION C - CILL DETAIL Scale 1:2

GLAZING SPECIFICATION:

- Primer the timber rebate with an oil based paint. (Note: Linseed oil based paints are not suitable as an undercoat).
- Drill 2 holes 6–8mm, from the inside out in the horizontal lower cill.
- Apply the Kawo Elastokitt to the rebate.
- Install the glass unit using 1.5mm thick hardwood spacers to all side within the zone of the sealant and secure with sprigs.
- Fill the clearance between the glass and frame with the Kawo Elastokitt sealant.
- Using the Elastokitt as a putty, fill the remainder of the rebate (min.7mm).
- Window to be decorated with oil based paint (Not linseed oil paint) completely covering the putty and overlapping onto the glass 1–2mm.
- Apply Kawo Elastokitt on the inside to seal gap between the glass and frame.

Rev.	Drawn	Comments.	Date

Applicant:
Mr & Mrs James.

Project:
Proposed Extension & Alterations
at The Old Post Office,
Endon Village,
Endon
Staffordshire. ST9 9EX.

Title:
Window W01 Detail

Status:
Planning

Scale at Size A3:	Date:	Drg.
1:10 1:2	14-12-16	1440-03

NOTE: This drawing is not to be used for construction unless Status marked 'Issued for Construction'

A.C.BAILEY
Plot 1, Stanley Bank, Stanley, Staffordshire. ST9 9LT.
T:01782 503302 - 07711 870008 E:office@planstobuild.co.uk