From:	planningcomments@staffsmoorlands.gov.uk
To:	Planning Comments (SMDC)
Subject:	Comment Received from Public Access
Date:	27 March 2017 09:33:28

Application Reference No. : SMD/2017/0126
Site Address: Land Adjacent High View Sutherland Road Longsdon Staffordshire
Comments by: Terence Woolliscroft
From:

Phone:
Email:
Submission: Neither
Comments: Could I point out a possible mistake on the Application Number SMD/2017/0126.

I refer to Section 11 ¿ Foul Sewage.

The document states that foul sewage will be disposed of by Mains Sewer. Actually, there are no mains sewers in this area and all properties are connected to either septic tank or cess pit.

T Woolliscroft