

Mr Williamson,

With reference to your query regarding the earth bund / retaining works that have been carried out at the above site, we have checked with the Designers (Messrs. David Symonds Associates) and they have confirmed that the reinforced earth structure, and piled wall beyond, were specifically designed to enable the development of the site. Provided excavation on site is no deeper than the level shown on their 'As Built' drawing no. 214538-S 11 'Excavation Limitation Plan', the proposed development will not affect the stability of the retaining structures – see email response from Jonathan Symonds to my colleague below.

(We have attached a pdf copy of David Symonds Associates drawing no. 214538-S 11 for your information - the site area referred to is cross-hatched and is at the base of the reinforced earth bund).

Should the development go ahead, we would expect a Structural Engineer to be able to design adequate foundations for the proposed buildings to remain within the depth constraints referred to above.

We are currently looking at the amended elevations and hope to have something to you by the end of next week, at the latest.

Regards,

Neil



ARCHITECTURE DESIGN DEVELOPMENT Limited

Caledonian House, Tatton Street, Knutsford, Cheshire. WA16 6AG
e-mail : neil.green@add-knutsford.co.uk Tel : 01565 750775