From: Thomas, Rhiannon <Rhiannon.Thomas@severntrent.co.uk>
Sent: 08 January 2018 13:47
To: Planning (SMDC)
Subject: stw ref: 2018010537353 / lpa ref: SMD/2017/0799 / 90 Springfield House Queen Street Cheadle

Good Day,

Thank you for the opportunity to comment on this planning application. Please find our response noted below:

With Reference to the above planning application the company's observations regarding sewerage are as follows.

I can confirm that we have no objections to the proposals subject to the inclusion of the following condition:

- The development hereby permitted should not commence until drainage plans for the disposal of foul and surface water flows have been submitted to and approved by the Local Planning Authority, and
- The scheme shall be implemented in accordance with the approved details before the development is first brought into use. This is to ensure that the development is provided with a satisfactory means of drainage as well as to prevent or to avoid exacerbating any flooding issues and to minimise the risk of pollution.

Severn Trent Water advise that there is a public sewer located within this site. Public sewers have statutory protection and may not be built close to, directly over or be diverted without consent. You are advised to contact Severn Trent Water to discuss the proposals. Severn Trent will seek to assist in obtaining a solution which protects both the public sewer and the building. Please note, when submitting a Building Regulations application, the building control officer is required to check the sewer maps supplied by Severn Trent and advise them of any proposals located over or within 3 meters of a public sewer. Under the provisions of Building Regulations 2000 Part H4, Severn Trent can direct the building control officer to refuse building regulations approval.

Clean Water Comments

We have apparatus in the area of the planned development, the developer will need to contact Severn Trent Water, New Connections team as detailed below to assess their proposed plans for diversion requirements.

To request a water map please follow the link, , https://www.stwater.co.uk/building-and-developing/estimators-and-maps/request-a-water-sewer-map/ select "Water and / or Sewer map request form" fill out the relevant details and fee payment and return to:

Severn Trent Water, Asset Data Management,
GISmapping Team, PO Box 5344, Coventry, CV3 9FT
Fax: 02477 715862
e-mail: GISmapping@severntrent.co.uk

Any correspondence and diversion applications are to be submitted through New Connections, the relevant form can be found on the Severn Trent website at https://www.stwater.co.uk/building-and-developing/other-developments/diversions/ Please click on download water diversion application form and complete the form as fully as possible.

Information on diversion application charges can be found https://www.stwater.co.uk/building-and-developing/regulations-and-forms/application-forms-and-guidance in "Our Charges" - Developer Charges 2015-2016 in Section 5.

Please attach all the relevant documentation and relevant fee and return the form to:

Severn Trent Water Ltd
PO Box 5311
Coventry
CV3 9FL
Telephone: 0800 707 6600
Email: new.connections@severntrent.co.uk

Please note it you wish to respond to this email please send it to Planning.apwest@severntrent.co.uk where we will look to respond within 10 working days. Alternately you can call the office on 01902 793851.

If your query is regarding drainage proposals, please email to the aforementioned email address and mark for the attention of Rhiannon Thomas (Planning Liaison Technician).

Kind regards,

Asset Protection Team
Severn Trent

Asset Protection (West)
Severn Trent Water - Waste Water Services
Tel: 01902 793851
email: Planning.apwest@severntrent.co.uk

****

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ

This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations.

To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in

relation to this email including liability arising from any external breach of security or

confidentiality or for virus infection or for statements made by the sender as these

are not necessarily made on behalf of the Companies.

Reduce waste! Please consider the environment before printing this email