The Coal Authority

INVESTOR IN PEOPLE

RTPI Learning Partner

200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority

For the Attention of: Lisa Jackson – Case Officer
Staffordshire Moorlands District Council

[By Email: planning@staffsmoorlands.gov.uk]

04 February 2019

Dear Lisa Jackson

PLANNING APPLICATION: INV-SMD/2019/0041

Proposed extension to existing stables and creation of manege; Land Off, Tower Hill Road, Mow Cop, Staffordshire, ST7 3PS

Thank you for your consultation letter of 29 January 2019 seeking the views of The Coal Authority on the above planning application.

The Coal Authority is a non-departmental public body sponsored by the Department of Business, Energy & Industrial Strategy. As a statutory consultee, The Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority Response: **Material Consideration**

I have reviewed the proposals and confirm that the application site falls within the defined Development High Risk Area.

Therefore within the application site and surrounding area there are coal mining features and hazards which need to be considered in relation to the determination of this planning application.

The Coal Authority records indicate the presence of coal outcrops crossing the application site which may have been subjected to unrecorded coal mining at shallow depth.

The Coal Authority Recommendation to the LPA

As you will be aware, the Coal Authority's general approach in cases where development is proposed within the Development High Risk Area is to recommend that the applicant obtains coal mining information for the application site and submits a Coal Mining Risk Assessment to support the planning application.

However, when considering the nature of this planning application and the type of structure, on the basis no substantial foundations or earthworks are required, The Coal Authority **does not object** to this planning application.

In the interests of public safety, however, the Coal Authority would recommend that, should planning permission be granted for this proposal, the following wording is included as an Informative Note within the Decision Notice:

The proposed development lies within an area that has been defined by the Coal Authority as containing potential hazards arising from former coal mining activity. These hazards can include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and previous surface mining sites. Although such hazards are seldom readily visible, they can often be present and problems can occur in the future, particularly as a result of development taking place.

It is recommended that information outlining how the former mining activities affect the proposed development, along with any mitigation measures required (for example the need for gas protection measures within the foundations), be submitted alongside any subsequent application for Building Regulations approval (if relevant).

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Coal Authority Permit. Such activities could include site investigation boreholes, digging of foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Failure to obtain a Coal Authority Permit for such activities is trespass, with the potential for court action.

Property-specific summary information on past, current and future coal mining activity can be obtained from: www.groundstability.com or a similar service provider.

If any coal mining features are unexpectedly encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848. Further information is available on the Coal Authority website at: www.gov.uk/government/organisations/the-coal-authority

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours Sincerely,

George Weightman

George Weightman | BSc (Hons), MSc
Trainee Planning Liaison Manager

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.

In formulating this response The Coal Authority has taken full account of the professional conclusions reached by the competent person who has prepared the Coal Mining Risk Assessment or other similar report. In the event that any future claim for liability arises in relation to this development The Coal Authority will take full account of the views, conclusions and mitigation previously expressed by the professional advisers for this development in relation to ground conditions and the acceptability of development.