

Dealt with by: Environmental Health

Our Ref: SMD/2021/0357

Direct Dial:

Your Ref: smd/2021/0357

Email: EHealth.

Date: 21st September 2021

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION

**Moorside Farm Ellastone Road
Cauldon Low**

PROPOSED DEVELOPMENT

The proposed change of use of an existing cow byre into a small business unit including a new toilet, office, workshop and stock storage room

Potential Areas Of Environmental Concern.

1. Construction Impacts - Condition
2. Plant and Machinery/ Operational Noise - Condition
3. Artificial Lighting – condition
4. Land Contamination - Condition
5. Asbestos - Advisory

Comments: The application indicates no industrial or commercial processes and machinery yet the application is for a workshop. The site is adjacent to an existing wood processing unit which industrial noise. We would advise any noise emitted from this site does not exceed background noise sound levels (condition advised).

Recommendation:

The Environmental Health Department have no objections subject to the following conditions or similar being applied to any permission granted.

Artificial Lighting

1. Details of floodlighting of the site shall be submitted to and approved in writing by the Local Planning Authority prior to the commencement of the development. The artificial lighting incorporated into this site in connection to this application shall not increase the pre-existing illuminance at the adjoining light sensitive locations (residential) when the light (s) is (are) in operation.

Reason: *To protect the local amenities of the local residents by reason of excess of luminance.*

Plant and Machinery Noise

2. The machinery, plant or equipment including installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated that the noise generated by the operation of the machinery shall not increase the background noise levels during day time expressed as LA90 [1hour] (day time 07:00-23:00 hours) and/or (b) LA90 [15 mins] during night time (night time 23:00-07:00 hours) at any adjoining noise sensitive locations or premises in separate occupation above that prevailing when the machinery is not operating. Noise measurements for the purpose of this condition shall be pursuant to BS 4142:2014.

Reason:- *To safeguard the amenity of local residents and that of the surrounding area from noise disturbance.*
noise disturbance.

Construction

3. No phase of the development hereby permitted shall take place except for works of site clearance and demolition until a Construction and Environmental Management Plan for that phase of the site has been submitted to and approved in writing by the Local Planning Authority, which shall include the following details:-
 - I. the hours of work, which shall not exceed the following: Construction and associated deliveries to the site shall not take place outside 08:00 to 18:00 hours Mondays to Fridays, and 08:00 to 13:00 hours on Saturdays, nor at any time on Sundays or Bank Holiday;
 - II. the arrangements for prior notification to the occupiers of potentially affected properties;
 - III. the responsible person (e.g. site manager / office) who could be contacted in the event of complaint;
 - IV. a scheme to minimise dust emissions arising from construction activities on the site.
 - V. any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment.

All works shall be carried out in accordance with the approved details. Any alteration to this Plan shall be approved in writing by the Local Planning Authority prior to commencement of the alteration.

Reason: *To protect the amenities of the area amenity of local residents and that of the surrounding area from noise disturbance.*

Unexpected Contamination

4. In the event that contamination is found at any time when carrying out the approved development it must be reported in writing immediately to the Local Planning Authority. Development should not commence further until an initial investigation and risk assessment has been completed in accordance with a scheme to be agreed by the Local Planning Authority to assess the nature and extent of any contamination on the

site. If the initial site risk assessment indicates that potential risks exist to any identified receptors, development shall not commence until a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property, and the natural and historical environment has been prepared, and is subject to the approval in writing of the local planning authority.

Following completion of measures identified in the approved remediation scheme and prior to bringing the development into first use, a verification report that demonstrates the effectiveness of the remediation carried out must be produced, and is subject to the approval in writing of the Local Planning Authority.

Soil Importation

5. No soil or fill material is to be imported to the site until it has been tested for contamination and assessed for its suitability for the proposed development; a suitable methodology for testing this material should be submitted to and agreed by the Local Planning Authority prior to the soils being imported onto site. The methodology should include the sampling frequency, testing schedules, criteria against which the analytical results will be assessed (as determined by the risk assessment) and source material information. The analysis shall then be carried out and validatory evidence submitted to and approved in writing to by the Local Planning Authority.

Reason (common to 4-5):- To ensure that the proposed development meets the requirements of the National Planning Policy Framework in that all potential risks to human health, controlled waters and wider environment are known and where necessary dealt with via remediation and or management of those risks.

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- Asbestos: A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition/renovation of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>
- Any approved noise scheme and measurements should pay due regard to British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014 Methods for rating and assessing industrial or commercial sound and/or the Building Regulations 2010 Document E or other appropriate guidance.

- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>
- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
 - The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
 - Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456)
- If required, contamination risk assessments shall be carried out in accordance with UK policy and with the procedural guidance relating to the contaminated land regime, and should be in accordance with Planning Policy Statement 23 and the CLR Report Series 1-12.
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an "appropriate person". In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site, the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Protection Department and agreed in principle prior to site investigation works being undertaken. The Environmental Protection Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,

Environmental Health