

Dealt with by: Environmental Health

Our Ref: SMD/2021/0513

Direct Dial:

Your Ref:

Email:

Date: 29th September 2021

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION

**The Croft Dilhorne Road
Dilhorne**

PROPOSED DEVELOPMENT

**Erection of replacement stable block and formation of
menage**

Potential Areas Of Environmental Concern.

1. Noise during demolition and construction
2. Manure Storage/ Odours
3. Waste disposal
4. Amplified music / voice
5. Lighting

General Comments

Manure: There is no information provided in regard to the disposal of horse manure. It may be advisable to apply the condition set out below in order to protect the local environment, soil and water.

Noise: The primary cause of noise from equestrian training centres/units can be the use of amplified sound and voice, it may be advisable to apply a condition ensuring that use of amplification is controlled such that the amenity of the area and nearby residents is not compromised.

Light: The nearest properties appear to be remote to this site but it maybe advised to apply the following condition to any permission granted. The lights should be appropriately directed in order to avoid light spillage and glare.

Demolition Advisory: A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>

Recommendation

The Environmental Health Department have no objection in principle subject to the following or similar conditions being applied to any permission granted.

1. Construction & Demolition works: Time of operations

Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.

- **08:00 - 18:00 hours (Monday to Friday);**
- **08:00 - 13:00 hours (Saturday)**
- **No working is permitted on Sundays or Bank Holidays.**

In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: *To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.*

2. Manure

Manure generated from the approved use should be collected and stored in a dedicated storage area, with sufficient capacity to store 6 months worth of manure. The manure storage area should have an impermeable surface capable of containing, or facilitating the collection of, all manure generated leachate and sited at least 50m from all neighbouring residential properties. The burning of manure as a means of disposal is not permitted.

Reason: *To protect the amenity of neighbours and pollution of the environment.*

3. Waste

Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment.

Reason: *To protect the amenities of the area.*

4. Lighting

The artificial lighting incorporated into this site in connection to this application shall not increase the pre-existing illuminance at the adjoining light sensitive locations when the light (s) is (are) in operation. Details of all artificial lighting to be installed under this permission should be submitted to and approved by the Local Planning Authority prior to development commencing.

Reason: *To protect the local amenities of the local residents by reason of excess of illuminance*

5. Noise :PA Sytems

No amplified sound shall be audible within or at the boundary of any noise sensitive (occupied) premises either attached to or in the vicinity of the premises to which this application refers.

Reason: *To ensure that the reasonable residential amenities of adjoining properties are adequately protected from noise pollution.*

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- The site is situated within a nitrate vulnerable zone and therefore manure disposal must therefore comply with the Nitrate Pollution Prevention Regulations 2008
- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>
- <https://www.theilp.org.uk/documents/obtrusive-light/>
- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
 - The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
 - Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456)

Regards

Environmental Health