

Mucklow & Harris Ltd					Page 1
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA		Fole Dairy Storm Area C			
Date 09/09/2021 File Area C.SRCX		Designed by RAA Checked by AM			
Innovyze		Source Control 2019.1			
<u>Summary of Results for 100 year Return Period (+40%)</u>					
Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m³)	Status
15 min Summer	110.265	0.265	15.0	7.9	O K
30 min Summer	110.281	0.281	15.0	8.4	O K
60 min Summer	110.237	0.237	14.9	7.1	O K
120 min Summer	110.171	0.171	13.5	5.1	O K
180 min Summer	110.143	0.143	10.9	4.3	O K
240 min Summer	110.126	0.126	9.1	3.8	O K
360 min Summer	110.106	0.106	6.9	3.2	O K
480 min Summer	110.094	0.094	5.6	2.8	O K
600 min Summer	110.086	0.086	4.8	2.6	O K
720 min Summer	110.079	0.079	4.2	2.4	O K
960 min Summer	110.070	0.070	3.4	2.1	O K
1440 min Summer	110.059	0.059	2.5	1.8	O K
2160 min Summer	110.050	0.050	1.8	1.5	O K
2880 min Summer	110.045	0.045	1.4	1.3	O K
4320 min Summer	110.038	0.038	1.0	1.1	O K
5760 min Summer	110.034	0.034	0.8	1.0	O K
7200 min Summer	110.031	0.031	0.7	0.9	O K
8640 min Summer	110.028	0.028	0.6	0.8	O K
10080 min Summer	110.027	0.027	0.5	0.8	O K
15 min Winter	110.295	0.295	15.0	8.9	O K
30 min Winter	110.293	0.293	15.0	8.8	O K
Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)	
15 min Summer	126.113	0.0	14.4	12	
30 min Summer	84.299	0.0	19.3	21	
60 min Summer	53.779	0.0	24.6	36	
120 min Summer	33.149	0.0	30.3	66	
180 min Summer	24.624	0.0	33.8	96	
240 min Summer	19.809	0.0	36.2	126	
360 min Summer	14.513	0.0	39.8	186	
480 min Summer	11.640	0.0	42.6	246	
600 min Summer	9.801	0.0	44.8	306	
720 min Summer	8.511	0.0	46.7	368	
960 min Summer	6.807	0.0	49.8	490	
1440 min Summer	4.960	0.0	54.4	734	
2160 min Summer	3.606	0.0	59.4	1096	
2880 min Summer	2.873	0.0	63.1	1456	
4320 min Summer	2.082	0.0	68.6	2180	
5760 min Summer	1.655	0.0	72.7	2904	
7200 min Summer	1.384	0.0	76.0	3568	
8640 min Summer	1.195	0.0	78.7	4360	
10080 min Summer	1.057	0.0	81.2	5056	
15 min Winter	126.113	0.0	16.1	13	
30 min Winter	84.299	0.0	21.6	22	
©1982-2019 Innovyze					

Mucklow & Harris Ltd				Page 2	
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA		Fole Dairy Storm Area C			
Date 09/09/2021 File Area C.SRCX		Designed by RAA Checked by AM			
Innovyze		Source Control 2019.1			
<u>Summary of Results for 100 year Return Period (+40%)</u>					
Storm Event	Max Level (m)	Max Depth (m)	Max Control (l/s)	Max Volume (m³)	Status
60 min Winter	110.214	0.214	14.8	6.4	O K
120 min Winter	110.147	0.147	11.3	4.4	O K
180 min Winter	110.122	0.122	8.6	3.7	O K
240 min Winter	110.107	0.107	7.0	3.2	O K
360 min Winter	110.089	0.089	5.2	2.7	O K
480 min Winter	110.079	0.079	4.2	2.4	O K
600 min Winter	110.072	0.072	3.5	2.2	O K
720 min Winter	110.067	0.067	3.1	2.0	O K
960 min Winter	110.059	0.059	2.5	1.8	O K
1440 min Winter	110.050	0.050	1.8	1.5	O K
2160 min Winter	110.042	0.042	1.3	1.3	O K
2880 min Winter	110.038	0.038	1.0	1.1	O K
4320 min Winter	110.032	0.032	0.7	0.9	O K
5760 min Winter	110.028	0.028	0.6	0.8	O K
7200 min Winter	110.026	0.026	0.5	0.8	O K
8640 min Winter	110.024	0.024	0.4	0.7	O K
10080 min Winter	110.023	0.023	0.4	0.7	O K
Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Time-Peak (mins)	
60 min Winter	53.779	0.0	27.5	38	
120 min Winter	33.149	0.0	34.0	66	
180 min Winter	24.624	0.0	37.8	96	
240 min Winter	19.809	0.0	40.6	126	
360 min Winter	14.513	0.0	44.6	188	
480 min Winter	11.640	0.0	47.7	246	
600 min Winter	9.801	0.0	50.2	306	
720 min Winter	8.511	0.0	52.3	366	
960 min Winter	6.807	0.0	55.8	484	
1440 min Winter	4.960	0.0	61.0	732	
2160 min Winter	3.606	0.0	66.5	1092	
2880 min Winter	2.873	0.0	70.6	1468	
4320 min Winter	2.082	0.0	76.8	2120	
5760 min Winter	1.655	0.0	81.4	2840	
7200 min Winter	1.384	0.0	85.1	3544	
8640 min Winter	1.195	0.0	88.2	4328	
10080 min Winter	1.057	0.0	90.9	5240	
©1982-2019 Innovyze					

Mucklow & Harris Ltd		Page 3
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Dairy Storm Area C	
Date 09/09/2021 File Area C.SRCX	Designed by RAA Checked by AM	
Innovyze Source Control 2019.1		

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.000	Shortest Storm (mins)	15
Ratio R	0.362	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.061

Time (mins)	Area
From:	To: (ha)
0	4 0.061

©1982-2019 Innovyze

Mucklow & Harris Ltd		Page 4
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Dairy Storm Area C	
Date 09/09/2021 File Area C.SRCX	Designed by RAA Checked by AM	
Innovyze Source Control 2019.1		

Model Details

Storage is Online Cover Level (m) 111.800

Tank or Pond Structure

Invert Level (m) 110.000

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	30.0	0.700	0.0	1.400	0.0	2.100	0.0
0.100	30.0	0.800	0.0	1.500	0.0	2.200	0.0
0.200	30.0	0.900	0.0	1.600	0.0	2.300	0.0
0.300	30.0	1.000	0.0	1.700	0.0	2.400	0.0
0.400	30.0	1.100	0.0	1.800	0.0	2.500	0.0
0.401	0.0	1.200	0.0	1.900	0.0		
0.600	0.0	1.300	0.0	2.000	0.0		

Hydro-Brake® Optimum Outflow Control

Unit Reference	MD-SHE-0177-1500-0800-1500
Design Head (m)	0.800
Design Flow (l/s)	15.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	177
Invert Level (m)	110.000
Minimum Outlet Pipe Diameter (mm)	225
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.800	15.0
Flush-Flo™	0.288	15.0
Kick-Flo®	0.590	13.0
Mean Flow over Head Range	-	12.5

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	6.3	1.200	18.2	3.000	28.2	7.000	42.4
0.200	14.7	1.400	19.6	3.500	30.4	7.500	43.9
0.300	15.0	1.600	20.9	4.000	32.4	8.000	45.3
0.400	14.7	1.800	22.1	4.500	34.3	8.500	46.4
0.500	14.2	2.000	23.2	5.000	36.1	9.000	47.8
0.600	13.1	2.200	24.3	5.500	37.8	9.500	49.1
0.800	15.0	2.400	25.3	6.000	39.4		
1.000	16.7	2.600	26.3	6.500	40.9		

©1982-2019 Innovyze