

From: [Johnston, Christopher](#)
To: [Planning Comments \(SMDC\)](#)
Subject: FW: SMD/2021/0564 Felthouse Farm, Cheddleton
Date: 17 January 2022 11:53:01

From: Christopher Humphreys <Christopher.Humphreys@highpeak.gov.uk>
Sent: 14 January 2022 14:59
To: Johnston, Christopher <Christopher.Johnston@StaffsMoorlands.gov.uk>
Subject: FW: SMD/2021/0564 Felthouse Farm, Cheddleton

Hi Chris,

Just for your information, these are the conditions that I am proposing to attach to the Environmental Health chimney height approval for the biomass boilers associated with this application. As previously advised this is separate to the planning permission so just for your information:

1. The chimneys serving the ETA Hack 200 P furnaces shall not be less than a minimum of 9 meters in height above ground level and at least 1 metre above the roof apex, and shall not be fitted with any terminations (such as cap or cowl) that may impede the upward dispersion of pollutants.
2. The furnaces and associated ducting and chimneys shall, as a minimum, be serviced and cleaned in accordance with the manufacturer's instructions.
3. The furnaces shall be fitted with the associated flue gas recirculation.
4. Only the fuel as described in your Biomass Boiler Information Request Form, dated 18/10/2021, shall be burnt in the furnaces.

Kind regards,

Christopher Humphreys
Pollution Specialist Officer
Environmental Heath
Staffordshire Moorlands District Council & High Peak Borough Council

Landline: 01538 395400 Ext: 4456
