

From: [Planning.APWest](#)
To: [Anne Fox](#)
Cc: [Alexis Sanchez](#); [Planning \(SMDC\)](#)
Subject: RE: STW Ref: P-211124-34031 PF3 Building Discharge Drainage Planning Ref: DOC/2022/0024 Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ
Date: 19 May 2022 11:32:15

ST Classification: OFFICIAL PERSONAL

Good morning Anne,

We require a plan that shows the proposed discharge rate of surface water that you propose to discharge into the public surface water sewer.

Please note, we would require all surface water to discharge to the public surface water sewer, and not to public foul or combined sewers.

Please advise of your proposed surface water discharge rate, and clarify the proposed final outfall point.

Thank you,

Rhiannon

Rhiannon Thomas
Planning Work Management Technician

Asset Protection

Asset Strategy & Planning

Chief Engineer, Severn Trent Water

E-mail : Planning.APWest@severntrent.co.uk

