
From: Planning.APWest <Planning.APWest@severntrent.co.uk>
Sent: 03 October 2022 10:04
To: Anne Fox
Cc: Planning (SMDC)
Subject: RE: STW Ref: P-211124-34031 PF3 Building Discharge Drainage Planning Ref: DOC/2022/0024
Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

Categories:

ST Classification: OFFICIAL PERSONAL

Good day,

As previously stated:

“Manhole 0404 is not a STW combined sewer, but is a public foul sewer by design, and therefore we cannot permit any surface water discharge to this sewer.

There is a 375mm public surface water sewer located just south of the aforementioned public foul manhole (nearest manhole to site on this Public surface water sewer is manhole number 0405), there is also a public 225mm surface water sewer in Barnfield Road (nearest manhole to site on this Public surface water sewer is manhole number 9501).

We would insist that a surface water connection to a public surface water sewer is investigated, with the flows restricted as previously agreed (4.41 litres/second).”

Having spoken to my colleague today, we do not feel a Teams call with myself would be beneficial. I am unable to negotiate your proposals, and this would need to be discussed with the New Connections Team; For the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contact our Development Services Team (Tel: 0800 707 6600).

When this has been discussed and proposals agreed, please advise me accordingly.

Thank you,

Rhiannon

Rhiannon Thomas
Planning Work Management Technician

Asset Protection

Asset Strategy & Planning

Chief Engineer, Severn Trent Water

E-mail : Planning.APWest@severntrent.co.uk



From: > **Sent:** 20 May 2022 13:12

To: Planning.APWest <Planning.APWest@severntrent.co.uk>

Cc: Alexis Sanchez >; Planning (SMDC) <Planning@staffs Moorlands.gov.uk>; Martin Lythgoe <>

Subject: STW Ref: P-211124-34031 PF3 Building Discharge Drainage Planning Ref: DOC/2022/0024 Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

FAO Miss Rhiannon Thomas

Rhiannon

Thank you for your email below. Please find attached a technical statement identifying the proposed surface water flow calculations and discharge proposals for the above development, in line with your requirements.

Please could you confirm that this information now satisfies the requirements of the planning condition.

Please do not hesitate to contact me on 07837 888 475 should you wish to discuss the information in more detail.

Kind Regards

Anne Fox
Senior Engineer



Disclaimer : This message and any attachments are confidential and may be privileged. It is intended solely for the named addressee. If you have received this message in error, please notify the sender immediately and do not copy, forward or disclose its contents to any other party. Whilst every effort is made by Norder Design to ensure that the content of this message is free from viruses, no liability is accepted by our practice and your own independent tests on the attached should be carried out prior to opening.

From: Planning.APWest <Planning.APWest@severntrent.co.uk>

Sent: 19 May 2022 11:32

To: Anne Fox <>

Cc: Alexis Sanchez <>; Planning (SMDC) <Planning@staffs Moorlands.gov.uk>

Subject: RE: STW Ref: P-211124-34031 PF3 Building Discharge Drainage Planning Ref: DOC/2022/0024 Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

ST Classification: OFFICIAL PERSONAL

Good morning Anne,

We require a plan that shows the proposed discharge rate of surface water that you propose to discharge into the public surface water sewer.

Please note, we would require all surface water to discharge to the public surface water sewer, and not to public foul or combined sewers.

Please advise of your proposed surface water discharge rate, and clarify the proposed final outfall point.

Thank you,

Rhiannon

Rhiannon Thomas
Planning Work Management Technician

Asset Protection

Asset Strategy & Planning

Chief Engineer, Severn Trent Water

E-mail : Planning.APWest@severntrent.co.uk



From: Anne Fox <>

Sent: 18 May 2022 19:04

To: Planning.APWest <Planning.APWest@severntrent.co.uk>

Cc: Martin Lythgoe <>; 8655 <>; Alexis Sanchez <>

<>

Subject: STW Ref: P-211124-34031 PF3 Building Discharge Drainage Planning Ref: DOC/2022/0024 Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

FAO Miss Rhiannon Thomas

Rhiannon

Further to your email below, please could you give me a call on 07837 888 475 to discuss the drainage proposals at the above site to ensure I make a submission to meet your requirements.

We are under pressure to resolve this item by end of play tomorrow, so hopefully a quick discussion will help speed up this process.

Kind Regards

Anne Fox
Senior Engineer



Disclaimer : This message and any attachments are confidential and may be privileged. It is intended solely for the named addressee. If you have received this message in error, please notify the sender immediately and do not copy, forward or disclose its contents to any other party. Whilst every effort is made by Norder Design to ensure that the content of this message is free from viruses, no liability is accepted by our practice and your own independent tests on the attached should be carried out prior to opening.

From: Planning.APWest <Planning.APWest@severntrent.co.uk>

Sent: 18 May 2022 10:30

To: Alexis Sanchez <Alexis.Sanchez@severntrent.co.uk>

Subject: STW Ref: P-211124-34031 PF3 Building_ Discharge Drainage _ Planning Ref: DOC/2022/0024 Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

ST Classification: UNMARKED

Good day,

The submitted drainage plan shows foul sewage is to discharge to the public combined sewer, and surface water is proposed to discharge indirectly to a public surface water sewer, with no proposed discharge rate provided.

As this site as 'brownfield' – we require the use of soakaways to be investigated as a form of surface water discharge. If these are proven to not be feasible on site, we would consider an indirect connection but we do require a 30% betterment to the sites existing discharge, providing a CCTV survey proving the existing connection point is being utilised.

We therefore would ask that the drainage related condition is not discharged at this stage.

I trust you find the above in order, however, if you have any further enquiries then please do not hesitate to contact us at Planning.apwest@severntrent.co.uk.

Kindest regards,

Rhiannon

Miss Rhiannon Thomas - Planning Liaison Work Management Technician
Asset Protection (West)

email: Planning.apwest@severntrent.co.uk

From: Alexis Sanchez <>

Sent: 05 May 2022 11:40

To: Planning.APWest <Planning.APWest@severntrent.co.uk>;

Cc: 8655 <>; [Martin Lythgoe](mailto:Martin.Lythgoe@severntrent.co.uk) <>; Anne Fox <>

<>

Subject: URGENT_FAO: Rhiannon Thomas _8655 PF3 Building_ Discharge Drainage _ Planning Ref: DOC/2022/0024 _ STW Ref: P-211124-34031

Good morning Rhiannon,

I am writing to you in relation to your query issued on the 4th of April 2022 (see attached) regarding the discharge of conditions applications (Planning Ref: DOC/2022/0024), STW ref: P-211124-34031.

Cover Note for the new proposed building:

Site Location: Croda Europe Ltd, Barnfield Road Leek, ST13 5QJ

The new general industrial building has a footprint of 22m x 15.2m with an area of 335sqm approx.

The building is located over a previous hard-surface concrete area. The surface water that was collected from the hard surfacing is now collected by the roof and discharged to the existing private local drain pipework. Therefore, no increase in the surface water discharge rates is proposed. The surface water from the roof is collected via 2no RWPs to the west of the building, as can be seen in the attached proposed drainage strategy Layout drawings *8655-NDA-XX-XX-DR-C-1250-P4* and *8655-NDA-XX-XX-DR-C-1251-P4*.

The height of the proposed PF3 building is approx. 16.6m to the eaves from the external FFL. There are 4-storey levels, ground floor and three floors above.

The building is divided into a plant room area and a welfare zone:

1. The plant room area is fitted with drain channels at the ground floor level to evacuate spillages that might occur from the process above. Those spillages will be contained within the building via a RC bund and discharged to an existing effluent treatment plant on the site.
2. The welfare area has the following wetrooms:
 - a. Ground floor: Kitchenette sink and UWAT toilet.
 - b. First floor: Male toilet, Female toilet, and 1no sink in the Lab room.
 - c. Second floor: 1no Cleaner's room sink.

All the above will be discharged into the existing private combined sewer. The maximum occupation of the building will be 5no people at any point. Therefore, it is understood that the addition of the above will not overload the existing private combined system.

Please, see attached the proposed GA floor plans and the drainage layout and details.

I hope the above is enough to answer your queries. Should you require more information, please let us know.

Thank you.

Kind regards,

Alexis Sanchez BSc (Hons) Dip Arch RIBA
Project Architect



Disclaimer : This message and any attachments are confidential and may be privileged. It is intended solely for the named addressee. If you have received this message in error, please notify the sender immediately and do not copy, forward or disclose its contents to any other party. Whilst every effort is made by Norder Design to ensure that the content of this message is free from viruses, no liability is accepted by our practice and your own independent tests on the attached should be carried out prior to opening.

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external

breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email