

Dealt with by: Environmental Health

Our Ref: SMD/2022/0361

Direct Dial: (01538) 395400

Your Ref:

Email: n/a

Date: 6th October 2022

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION	Churnet Works Abbey Green Road Leek
PROPOSED DEVELOPMENT	Erection of freestanding restaurant with drive-thru facility, car parking, landscaping and associated works, including Customer Order Displays (COD) and Play Frame.

Potential Areas Of Environmental Concern.

1. Construction Impacts (Condition)
2. Unexpected Contamination (Condition)
3. Artificial Lighting (Separate Applications)
4. Plant and Machinery Noise (Condition)
5. Operational Noise (Condition noise assessment mitigation)
6. Delivery Noise (Condition)
7. Cooking smells (Condition)

General Comments

EV infrastructure (building Control)

The applicant is reminded that they will be required to instal EV / EV infrastructure in accordance with [Approved Document S: infrastructure for charging electric vehicles](#)

Air Quality

It would have been desirable if the applicant had submitted an AQ screen assessment in support of the application. However, it is noted that that there are no nearby receptors of concern (properties essentially) and the TA submitted indicates that it will generate minimal additional traffic outside of the immediate area. Providing this is accepted by Highways it is not considered that an AQW assessment is required in this instance.

Construction Impacts: Condition.

Contamination:

The application was supported by a [Phase 1 desk study by Ensaf Consultants \(Ref: 1664-16 / Final\)](#) . The report is considered and very good and comprehensive review of the potential contamination sources and previous site remediation that occurred at the site. The report concludes with a preliminary CSM and recommendations for further intrusive work to address the outstanding contamination that are likely to exist at the site. This is agreed and a condition is recommended.

Noise:

A noise assessment (acoustic assoc. sw ltd ref. 7586) has been submitted to address noise impacts which are typical of this development as the closest property to the development is approx. 60 m away. The potential noise impacts have been identified as car park, drive thru, vehicle noise, plant/machinery and delivery/waste collection noise.

The predicted impacts from the development are significantly lower than pre-existing background noise. Mitigation is proposed within the assessment (pg4 general, pg17 Plant attenuation, pg 20 Drive thru noise barrier 2.4m high). The assessment determines that with mitigation in place, adverse impacts to neighbouring residential properties can be prevented.

The site is traditionally industrial/commercial and the proposed use appears suitable subject to all appropriate mitigation being installed into the final construction. A condition is advised below to take account of plant/machinery and delivery noise.

Cooking smells: Condition

Recommendation

The Environmental Health Department have no objections subject to the following conditions being applied to any permission granted.

If consent is granted the following conditions are recommended:

1. Construction & Demolition Works: Time of operations

Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.

- 08:00 - 18:00 hours (Monday to Friday);
- 08:00 - 13:00 hours (Saturday)
- No working is permitted on Sundays or Bank Holidays.

In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.

2. Construction & Demolition: Pollution Control

- I. During construction/demolition phases amplified music and/or radios shall not be audible beyond the site boundary;
- II. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records should be retained for inspection by officers of the Local Planning Authority;
- III. No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely affect adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

Reason: *To protect the amenities of the area during construction*

3. Contamination

No development approved by this planning permission shall take place until a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, property (existing or proposed including buildings, crops, livestock, pets, woodland, service lines and pipes; buildings), adjoining land and ground and surface waters, has been submitted to and approved in writing by the Local Planning Authority. The scheme must include:

- a. A site investigation, based on the information already provided to support a detailed assessment of risks to all receptors that may be affected, including those off site.
- b. The results of the site investigation and the detailed risk assessment referred to in (a) and, based on these, an options appraisal and a remediation strategy giving full details of remediation objectives and remediation criteria
- c. A validation plan providing details of the data that will be collected in order to demonstrate that the all works set out in (a) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

If, during the course of development, any contamination is found which has not been identified in the site investigation, additional measures for the remediation of this source of contamination shall be submitted to and approved in writing by the local planning authority. The remediation of the site shall incorporate the approved additional measures.

The scheme must ensure that the site will not qualify as contaminated land under Part 2A of the Environmental Protection Act 1990 in relation to the intended use of the land after remediation.

4 Validation

Prior to bringing the development into first use, a validation report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to and approved, in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved validation plan to demonstrate that the site remediation criteria have been met. It shall also include any plan (a long-term monitoring and maintenance plan) for longer-term monitoring of

pollutant linkages, maintenance and arrangements for contingency action, as identified in the validation plan, and for the reporting of this to the local planning authority.

5. Importation of topsoil

No soil is to be imported to the site until it has been tested for contamination and assessed for its suitability for the proposed development; a suitable methodology for testing this material should be submitted to and agreed by the Local Planning Authority prior to the soils being imported onto site. The methodology should include the sampling frequency, testing schedules, criteria against which the analytical results will be assessed (as determined by the risk assessment) and source material information. The analysis shall then be carried out and validatory evidence submitted to and approved in writing to by the Local Planning Authority.

Reason (common to 3-5):- *To ensure that the proposed development meets the requirements of the National Planning Policy Framework in that all potential risks to human health, controlled waters and wider environment are known and where necessary dealt with via remediation and or management of those risks.*

6. Noise Control

All mitigation set out in the noise assessment (acoustic assoc. sw ltd ref. 7586) should be installed in full.

7. Plant and Machinery Noise

The rating level of sound emitted from [any fixed plant and/or machinery associated with the development] [industrial activities at the use hereby approved] shall not exceed background sound levels by more than 5 dB(A) between the hours of 07.00–23.00 (taken as a 15 minute LA90 at the nearest sound-sensitive premises) and shall not exceed the background sound level between 23.00–07.00 (taken as a 15 minute LA90 at the nearest/any sound-sensitive premises). All measurements shall be made in accordance with the methodology of BS4142 (2014 + A1:2019) (Methods for rating and assessing industrial and commercial sound) and/or its subsequent amendments.

Where access to the nearest sound-sensitive property is not possible, measurements shall be undertaken at an appropriate location and corrected to establish the noise levels at the nearest sound-sensitive property.

Any deviations from the LA90 time interval stipulated above shall be agreed upon in writing with the local planning authority.

8. Delivery Noise

The rating level of sound emitted from deliveries shall not exceed background sound levels by more than 5 dB(A) between the hours of 07.00–23.00 (taken as a 15 minute LA90 at the nearest sound-sensitive premises) and shall not exceed the background sound level between 23.00–07.00 (taken as a 15 minute LA90 at the nearest/any sound-sensitive premises). All measurements shall be made in accordance with the methodology of BS4142 (2014 + A1:2019) (Methods for rating and assessing industrial and commercial sound) and/or its subsequent amendments.

Where access to the nearest sound-sensitive property is not possible, measurements shall be undertaken at an appropriate location and corrected to establish the noise levels at the nearest sound-sensitive property.

Any deviations from the LA90 time interval stipulated above shall be agreed upon in writing with the local planning authority.

Reason (6-8): To protect the amenities of nearby residents

9. Cooking Smells

Prior to the commencement of development, a scheme containing full details of arrangements for internal air extraction, odour control, and discharge to atmosphere from cooking operations, including any external ducting and flues, shall be submitted to and approved in writing by the local planning authority. The works detailed in the approved scheme shall be installed in their entirety before the use hereby permitted is commenced. The equipment shall thereafter be maintained in accordance with the manufacturer's instructions and operated at all times when cooking is being carried out unless otherwise agreed beforehand in writing with the local planning authority. The equipment shall be installed and in full working order to the satisfaction of the Local Planning Authority prior to the commencement of use. (Any system installed must be by suitably qualified competent engineers and the canopy must meet all relevant Health and Safety requirements including the use of Gas Interlocks. The provision of a commissioning certificate issued by a Gas Safe registered engineer should be available for inspection.)

Reason: *To ensure that unsatisfactory cooking odours outside the premises are minimised, in the interest of the amenity of occupiers of nearby properties.*

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>
- Any approved noise scheme and measurements should pay due regard to the Professional Guidance on Planning and Noise (ProPG), British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014 Methods for rating and assessing industrial or commercial sound and/or the Building Regulations 2010 Document E or other appropriate guidance
- Any approved foul drainage system should meet the British Standard 6297:2007+A1:2008: Code of practice for the design and installation of drainage fields for use in wastewater treatment <http://www.bsigroup.com>
- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>

- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
- If required, Contamination risk assessments shall be carried out in accordance with UK policy the Land contamination risk management framework (LCRM), published by the Environment Agency <https://www.gov.uk/government/publications/land-contamination-risk-management-lcrm>
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an "appropriate person". In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site, the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Protection Department and agreed in principle prior to site investigation works being undertaken. The Environmental Protection Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,
Environmental Health