From:	Curley, Jane
To:	Planning (SMDC)
Subject:	RE: CM: DOC/2022/0069 Compton Mill Leek. SMD/2021/0441
Date:	13 December 2022 12:20:55
Attachments:	image001.png

From: Whittaker, Roberta (EXT) <roberta.whittaker1@staffordshire.gov.uk>
Sent: 13 December 2022 12:18
To: Curley, Jane <jane.curley@staffsmoorlands.gov.uk>
Cc: Planning (SMDC) <Planning@staffsmoorlands.gov.uk>; Plant, David (E,I&S) <david.plant@staffordshire.gov.uk>
Subject: RE: CM: DOC/2022/0069 Compton Mill Leek. SMD/2021/0441

Good Afternoon Jane,

David has rightly flagged that we did recommend condition 29, and although we noted it as a compliance condition I have reviewed the CEMP and it does not mention control of surface water or water quality during the construction period so I wouldn't say that it is in compliance with condition 29 of SMD/2021/0441.

Kind Regards
Roberta

Christmas leave between 21/12/22 – 03/01/23

Please note my working days are Monday to Wednesday.

Staffordshire County Council

Flood Risk Management | Economy, Infrastructure and Skills
Staffordshire County Council, Lichfield Highways,
Trent Valley Road, Lichfield, WS13 6EU
Postal Address: 2 Staffordshire Place,
Tipping Street, Stafford, ST16 2DH
E-mail: **flood.team@staffordshire.gov.uk**
www.staffordshire.gov.uk