

From: [Whittaker, Roberta \(EXT\)](#)
To: [Curley, Jane](#)
Cc: kat.crisp@bartonwillmore.co.uk; [Planning \(SMDC\)](#)
Subject: RE: SMD/2022/0076 - Detailed Drainage Design
Date: 20 December 2022 13:10:00
Attachments: [image001.png](#)

Good Afternoon Jane,

Staffordshire County Council Flood Risk Management Position

Following the updated information provided by Kat we still require the following information before we would look to recommend conditions on this application.

Photograph of the existing outfall into the Trent– it is likely that the discharge route will need to be more formalised depending on findings – this hasn't been provided after multiple requests. We need to ensure that the site has a viable point of discharge before we can recommend conditions.

Please re-consult us at flood.team@staffordshire.gov.uk when amended details are received. If you are minded to approve the application contrary to this advice, we request that you contact us again to allow further discussion.

Kind Regards
Roberta

Christmas leave between 21/12/22 – 03/01/23

Please note my working days are Monday to Wednesday.



Flood Risk Management | Economy, Infrastructure and Skills
Staffordshire County Council, Lichfield Highways,
Trent Valley Road, Lichfield, WS13 6EU
Postal Address: 2 Staffordshire Place,
Tipping Street, Stafford, ST16 2DH
E-mail: flood.team@staffordshire.gov.uk
www.staffordshire.gov.uk