
From: Planning.APWest
Sent: 07 February 2023 11:10
To: Adam Gregory
Cc: Planning (SMDC)
Subject: stw ref P-220713-36823 / SMD/2022/0210 White Hart Hotel High Street Alton

Follow Up Flag: Follow up
Flag Status: Flagged

Categories:

22.02.2022 – email passed to planning support - marked as urgent due to the date this email came in. this email has not been put onto the website - sh

ST Classification: UNMARKED

Good day,

Your email has been passed onto me as you had emailed the incorrect department.

I can advise we would require clear plans showing the proposals for both foul sewage and surface water discharge from the proposed development.

NOTE: we would not permit a surface water discharge into the public foul sewer or public combined sewer, and recommend the applicant seeks alternative arrangements.

Please note if you wish to respond to this email please send it to Planning.apwest@severntrent.co.uk where we will look to respond within 10 working days.

If your query is regarding drainage proposals, please email to the aforementioned email address and mark for the attention of Rhiannon Thomas (Planning Liaison Technician).

Kind regards,

Rhiannon

Rhiannon Thomas
Planning Work Management Technician

Asset Protection
Asset Strategy & Planning
Chief Engineer, Severn Trent Water
E-mail :



From: Asset.Protection
Sent: 07 February 2023 10:43
To: Planning.APWest
Cc: Asset.Protection
Subject: FW: stw ref P-220713-36823 / SMD/2022/0210 White Hart Hotel High Street Alton

ST Classification: UNMARKED

Hi

One for planning

Thanks

Kind Regards

Caroline Graham
Asset Protection
Asset Strategy & Planning
Chief Engineer, Severn Trent Water
E-mail :

From: Adam Gregory
Sent: 06 February 2023 13:53
To: Asset.Protection
Cc: Robert Goodley
Subject: stw ref P-220713-36823 / SMD/2022/0210 White Hart Hotel High Street Alton

Dear Sir/ Madam,

Following your comments made on the above application, can you please advise exactly what works are required to satisfy the condition?

I can confirm that we have no objections to the proposals subject to the inclusion of the following condition:

- The development hereby permitted should not commence until drainage plans for the disposal of foul and surface water flows have been submitted to and approved by the Local Planning Authority, and

Can you advise if you require engineers calculations to meet particular flow rates? Or do you simply require locations of connections and drainage run layouts?

Regards

Adam Gregory
Director
Architectural Designer

M.

E. W.

www.forefrontdc.com



FOREFRONT

DEVELOPMENT CONSULTING LTD

4 Ridge House, Ridge House Drive, Festival Park, S-O-T. ST1 5SJ
Office 01782 216912 WWW.FOREFRONTDC.COM

The information contained in this message and any attachments is confidential and is intended for the sole use of the recipient(s) only. The unauthorised use, disclosure, copying or alteration of this message is strictly forbidden. Forefront Development Consulting Ltd has taken reasonable precautions to ensure that this message and any attachments are free from viruses, however It is the recipient's responsibility to carry out such virus checks on this message and any attachments as it deems necessary. Messages sent or received through our networks may be monitored to ensure compliance with the law, regulation and/or our policies. Please contact the sender and make them aware if you believe you have received this email in error.

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email