

DATE: 26 April 2023
DESIGNER: MMA Lighting Consultancy Ltd
PROJECT No: MMA17930
PROJECT NAME: Daisy Bank Farm, Upper Tean S38



Daisy Bank Farm, Upper Tean - Area Calculation - R0

6m Staffordshire CC Spec Columns with Holophane Vmax 3000K
LED Luminaires

BS5489-1:2020 - Lighting Class: P5
Eav 3.00 - 4.50 Lux
Emin 0.60 Lux

Base drawing number used in this calculation 'C1941-C-SK01
Layout Plan Engineering - 14.04.2023'

Outdoor Lighting Report

PREPARED BY: MMA Lighting Consultancy Ltd
99 Old Bath Road
Summer Field House
Charvil
Reading
Berkshire
RG10 9QN
Email: info@mma-consultancy.co.uk
Web: www.mma-consultancy.co.uk

Layout Report

General Data

Dimensions in Metres Angles in Degrees
Grid Origin 401250.6m x 339060.3m
Area 168.0m x 123.0m
Sample Spacing 1.50m x 1.50m

Luminaires

Luminaire A Data

Supplier	Holophane Council Pref
Type	VMX.2.LA033.V1.F4Q1.W016
Lamp(s)	LED C.3000 Lumens
Lamp Flux (klm)	2.29
File Name	VMX.2.LA033.V1.F4Q1.W016.IES
Maintenance Factor	0.86
Lum. Int. Class	G4
No. in Project	6

Layout

ID	Type	X	Y	Height	Angle	Tilt	Cant	Out-reach	Target X	Target Y	Target Z
1	A	401278.34	339143.21	6.00	300.00	0.00	0.00	0.40			
2	A	401307.13	339149.15	6.00	115.00	0.00	0.00	0.40			
3	A	401336.84	339158.29	6.00	252.00	0.00	0.00	0.40			
4	A	401363.81	339137.67	6.00	221.00	0.00	0.00	0.40			
5	A	401372.10	339107.57	6.00	31.00	0.00	0.00	0.40			
6	A	401390.76	339086.77	6.00	128.00	0.00	0.00	0.40			

Horizontal Illuminance (lux)

Grid 1




Results

Eav	4.03
Emin	0.80
Emax	8.70
Emin/Emax	0.09
Emin/Eav	0.20

Horizontal Illuminance (lux)

Grid 1



Results

Eav	4.03
Emin	0.80
Emax	8.70
Emin/Emax	0.09
Emin/Eav	0.20