

Dealt with by: Environmental Health

Our Ref: SMD/2023/0201

Direct Dial: (01538) 395400

Your Ref: as above

Email: EHealth.Consultation@highpeak.gov.uk

Date: 13th July 2023

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION

**Wood Farm Red Road
Alton**

PROPOSED DEVELOPMENT

**Storage Buildings for Agricultural / Forestry purpose for
produce and equipment**

Potential Areas Of Environmental Concern:

1. Construction Impacts (condition)
2. Importation of "Fill" material (Condition)
3. Unexpected Contamination (Condition)
4. Lighting (Condition)
5. Plant/Machinery Noise (Condition)

General Comments.

Amenity: The application is for agricultural storage buildings. Though the proposed units are remote and a significant distance from the nearest neighbouring properties there is a proposal for buildings 2/3 to be used for work during inclement weather. The application form states there will be no industrial/commercial processes or machinery, we would advise a condition is imposed on any permission granted to ensure any machinery used in the buildings does not increase background sound levels when in operation. Conditions are advised to ensure the development does not adversely impact the local environment and neighbourhood amenity.

Recommendation

The Environmental Health Section have no objection in principle subject to condition.

Construction & Demolition works: Time of operations

1. Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.
 - **08:00 - 18:00 hours (Monday to Friday);**
 - **08:00 - 13:00 hours (Saturday)**
 - **No working is permitted on Sundays or Bank Holidays.**

In this instance a noisy activity is defined as any activity (for instance, but not restricted to,

building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: *To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.*

2. Construction & Demolition: Pollution Control

- I. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records should be retained for inspection by officers of the Local Planning Authority;
- II. No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely affect adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

Reason: *To protect the amenities of the area during construction*

3. Importation of Fill Material

No fill material, used in connection with the above development or any associated farm track, is to be imported to the site until it has been tested for contamination and assessed for its suitability for the proposed development. A methodology for demonstrating the material is suitable for its proposed use, should be submitted too and agreed by the Local Planning Authority prior to the material being imported.

4. Unexpected Contamination

In the event that contamination is found at any time when carrying out the approved development it must be reported in writing immediately to the Local Planning Authority. Development should not commence further until an initial investigation and risk assessment has been completed in accordance with a scheme to be agreed by the Local Planning Authority to assess the nature and extent of any contamination on the site. If the initial site risk assessment indicates that potential risks exist to any identified receptors, development shall not commence until a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property, and the natural and historical environment has been prepared, and is subject to the approval in writing of the local planning authority. Following completion of measures identified in the approved remediation scheme and prior to bringing the development into first use, a verification report that demonstrates the effectiveness of the remediation carried out must be produced, and is subject to the approval in writing of the Local Planning Authority.

Reason (3 and 4):- *To ensure that the proposed development meets the requirements of the National Planning Policy Framework in that all potential risks to human health, controlled waters and wider environment are known and where necessary dealt with via remediation and or management of those risks.*

5. Lighting

The artificial lighting incorporated into this site in connection to this application shall not increase the pre-existing illuminance or cause glare at the adjoining light sensitive locations when the light (s) is (are) in operation. Details of all artificial lighting to be installed under this permission should be submitted to and approved by the Local Planning Authority prior to development commencing.

Reason: *To protect the local amenities of the local residents by reason of excess of illuminance*

6. Plant and machinery Noise

The machinery, plant or equipment including air conditioning units installed or operated in connection with the carrying out of this permission shall be so enclosed and/or attenuated that the noise generated by the operation of the machinery shall not increase the background noise levels during day time expressed as LA90 [1hour] (day time 07:00-23:00 hours) and/or (b) LA90 [15 mins] during night time (night time 23:00-07:00 hours) at any adjoining noise sensitive locations or premises in separate occupation above that prevailing when the machinery is not operating. Noise measurements for the purpose of this condition shall be pursuant to BS 4142:2014. The details and location of any plant or machinery to be installed under this permission should be submitted to and approved of in writing by the Local Planning Authority.

Reason:- *To safeguard the amenity of local residents and that of the surrounding area from noise disturbance.*

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- During any demolition and construction activities (including landscaping) the contractor should take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
- The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
- Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456).
- The lighting scheme should comply with the Institution of Lighting Professionals Guidance Note for the reduction of obtrusive light 2011(or later versions). It should be designed so that it is the minimum needed for security and operational processes and be installed to minimise potential pollution caused by glare and spillage.

Illuminated area m ²	Zone E1	Zone E2	Zone E3	Zone E4
Up to 10.00	100	600	800	1000

Over 10.00	n/a	300	600	600
------------	-----	-----	-----	-----

Environmental Zones			
Zone	Surrounding	Lighting Environment	Examples
E0	Protected	Dark	UNESCO Starlight Reserves, IDA Dark Sky Parks
E1	Natural	Intrinsically dark	National Parks, Areas of Outstanding Natural Beauty etc.
E2	Rural	Low district brightness	Village or relatively dark outer suburban locations
E3	Suburban	Medium district brightness	Small town centres or suburban locations
E4	Urban	High district brightness	Town/city centres with high levels of night-time activity

The guidance advises that, where an area to be lit lies on the boundary of two zones or can be observed from another zone, the limits used should be those applicable to the most rigorous zone.

- Protecting our Water, Soil and Air, A Code of Good Agricultural Practice growers and land managers (Defra, 2009 [ISBN: 978 0 11 243284 5]), is available as a free download from the defra website: www.defra.co.uk

Regards
Environmental Health