

Dealt with by: Environmental Health

Our Ref: DET/2023/0032

Direct Dial: (01538) **Email:** n/a

Your Ref:

Date: 4th December 2023

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION

**F Ball And Co Ltd, Station Road, Cheddleton,
Staffordshire, ST13 7RS**

PROPOSED DEVELOPMENT

**Application to determine if prior approval is required for
a proposed: roof mounted 380.90kW solar PV system
comprising of 929 x 410w Canadian Solar modules.**

Potential Areas Of Environmental Concern.

1. Construction Impacts (Condition)
2. Plant and Machinery Noise (Condition)
3. Solar Panels Glare (Advisory)

General Comments

Noise: Although solar panel developments cause relatively low noise impacts during the operational phase any inverters or batteries installed can cause noise impacts especially during periods of low background noise. There is a plant and machinery noise condition advised below.

Glare: The solar screens should be sufficiently screened so as not to cause glare to any nearby neighbouring properties. It would be advisable that a condition is placed on the permission to ensure where there is potential for glare to impact on neighbouring properties that mitigation steps are taken in the form of screening to prevent this problem.

Recommendation

The Environmental Health Department have no objections subject to the following conditions being applied to any permission granted.

1. Construction and demolition works: Timings

Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.

- 08:00 - 18:00 hours (Monday to Friday);
- 08:00 - 13:00 hours (Saturday)
- No working is permitted on Sundays or Bank Holidays.

In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.

2. Construction & Demolition: Pollution Control

- I. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records should be retained for inspection by officers of the Local Planning Authority;
- II. No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely affect adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

Reason: *To protect the amenities of the area during construction*

3. Plant and Machinery Noise

The rating level of sound emitted from [any fixed plant and/or machinery associated with the development] [commercial activities at the use hereby approved] shall not exceed background sound levels by more than 5 dB(A) between the hours of 07.00–23.00 (taken as a 15 minute LA90 at the nearest sound-sensitive premises) and shall not exceed the background sound level between 23.00–07.00 (taken as a 15 minute LA90 at the nearest/any sound-sensitive premises). All measurements shall be made in accordance with the methodology of BS4142 (2014 + A1:2019) (Methods for rating and assessing industrial and commercial sound) and/or its subsequent amendments.

Where access to the nearest sound-sensitive property is not possible, measurements shall be undertaken at an appropriate location and corrected to establish the noise levels at the nearest sound-sensitive property.

Any deviations from the LA90 time interval stipulated above shall be agreed in writing with the local planning authority.”

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- Any approved noise scheme and measurements should pay due regard to the Professional Guidance on Planning and Noise (ProPG), British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014

Methods for rating and assessing industrial or commercial sound and/or the Building Regulations 2010 Document E or other appropriate guidance

- Any approved foul drainage system should meet the British Standard 6297:2007+A1:2008: Code of practice for the design and installation of drainage fields for use in wastewater treatment <http://www.bsigroup.com>
- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>
- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
 - The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
 - Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456)
- If required, Contamination risk assessments shall be carried out in accordance with UK policy the Land contamination risk management framework (LCRM), published by the Environment Agency <https://www.gov.uk/government/publications/land-contamination-risk-management-lcrm>
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an "appropriate person". In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site, the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Protection Department and agreed in principle prior to site investigation works being undertaken. The Environmental Protection Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order

to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,

Environmental Health