

From: [Planning.APWest](#)
To: [Planning \(SMDC\)](#)
Subject: stw ref P-231211-42329 / SMD/2022/0371 - SMD/2023/0610 / 22 The Beeches Jasmine Close Blythe Bridge
Date: 23 January 2024 11:23:56

ST Classification: UNMARKED

Good Day,

Thank you for the opportunity to comment on this planning application. Please find our response noted below:

With Reference to the above planning application the company's observations regarding sewerage are as follows.

I can confirm that we have no objections to the proposals subject to the inclusion of the following condition:

- The development hereby permitted should not commence until drainage plans for the disposal of foul and surface water flows have been submitted to and approved by the Local Planning Authority, and
- The scheme shall be implemented in accordance with the approved details before the development is first brought into use. This is to ensure that the development is provided with a satisfactory means of drainage as well as to prevent or to avoid exacerbating any flooding issues and to minimise the risk of pollution.

Severn Trent Water advise that there is two 750mm public combined sewers located within this site. Public sewers have statutory protection and may not be built close to, directly over or be diverted without consent. You are advised to contact Severn Trent Water to discuss the proposals. Severn Trent will seek to assist in obtaining a solution which protects both the public sewer and the building. Please note, when submitting a Building Regulations application, the building control officer is required to check the sewer maps supplied by Severn Trent and advise them of any proposals located over or within 3 meters of a public sewer. Under the provisions of Building Regulations 2000 Part H4, Severn Trent can direct the building control officer to refuse building regulations approval.

Please note that there is no guarantee that you will be able to build over or close to any Severn Trent sewers, and where diversion is required there is no guarantee that you will be able to undertake those works on a self-lay basis. Every approach to build near to or divert our assets has to be assessed on its own merit and the decision of what is or isn't permissible is taken based on the risk to the asset and the wider catchment it serves. It is **vital** therefore that you contact us at the earliest opportunity to discuss the implications of our assets crossing your site. Failure to do so could significantly affect the costs and timescales of your project if it transpires diversionary works need to be carried out by Severn Trent.

NO BUILD ZONE: 300mm to 999mm diameter - 5m either side of the pipe, measured from the centreline of the sewer.

NOTE: we would not permit a surface water discharge into the public combined sewer, and recommend the applicant seeks alternative arrangements – please note, we would insist soakaways and other SUD techniques are investigated before considering a discharge to the public surface water sewer with restricted rates.

NOTE: we would strongly recommend the Developer/Applicant to make contact with STW and look to submit a Development Enquiry for this development site; this will discuss the drainage proposals for site, and if any issues, look to resolve them. It is best to visit our website:

<https://www.stwater.co.uk/building-and-developing/new-site-developments/developer-enquiry/> and follow the application form guidance to begin this process.

IMPORTANT NOTE: This response only relates to the public waste water network and does not

include representation from other areas of Severn Trent Water, such as the provision of water supply or the protection of drinking water quality.

Please note if you wish to respond to this email please send it to Planning.apwest@severntrent.co.uk where we will look to respond within 10 working days.

If your query is regarding drainage proposals, please email to the aforementioned email address and mark for the attention of Planning Liaison Technician.

Kind regards,

Asset Protection Team

Severn Trent

Asset Protection (West)

Severn Trent Water - Waste Water Services

email: Planning.apwest@severntrent.co.uk

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email