

From: [Building Over](#)
To: [Planning \(SMDC\)](#)
Subject: RE: External Consultation Letter - App ref SMD/2024/0053
Date: 02 February 2024 14:02:55
Attachments: [image001.png](#)

ST Classification: UNMARKED

Dear Sir or Madam

Thank you for your consultation.

Having reviewed our statutory sewer records, they demonstrate the following sewer with associated protective strip:

- 150mm diameter foul sewer – with a protective strip of 3m either side of the pipe, thus providing 6m across the diameter to the pipe

In the interest of being environmental friendly, encouraging the reduction the of paper, we politely request you direct your client to our website to obtain our application forms:

<https://www.stwater.co.uk/building-and-developing/overview/building-over-sewers/>

If they have any enquiries with the application process, they're welcome to contact us via email or telephone ()

Kind Regards,

Mrs Jasveer Bullock

Building Overs Planning Technician

Network Solutions

Developer Services

Tel:

Email:

For further information on building close to or over a public sewer, please follow the link below:

<https://www.stwater.co.uk/building-and-developing/house-developments/house-renovation/building-over-sewers/>

We have listened to our customers and local communities and Severn Trent have made a pledge to transform and protect the health of our Rivers, for more information please follow the link below:

<https://www.stwater.co.uk/get-river-positive/our-river-pledges/>

WONDERFUL ON TAP



