

From: [EHealth Consultation](#)
To: [Hannah Varley](#)
Cc: [Planning \(SMDC\)](#)
Subject: FW: pp ref DOC/2024/0007 Victoria Business Park _ Flue and Gas Risk Discharge
Date: 18 March 2024 09:57:39
Attachments: [E_768953.DOC](#)
[image001.png](#)

Hi Hannah,

Further to the above:

As no external lighting or flue is to be installed condition 7 & 8 can be discharged.

Condition 10 - Gas Risk Assessment

The applicant has submitted details of the [basic gas protection membrane](#) (visqueen), that they are proposing to install.

This is accepted and the first part of the condition can be discharged.

However, for full discharge, the applicant must also demonstrate that they have installed the membrane correctly. E.g.

"Prior to the development being first brought into use, a validation report demonstrating completion of the works set out in the approved gas protection scheme shall be submitted to and approved in writing by the local planning authority".

All the best

Dan

Dr. Daniel McCrory Principal Pollution Officer

Environmental Health

High Peak Borough Council and Staffordshire Moorlands District Council

www.highpeak.gov.uk | Follow HPBC on X ([Formerly Twitter](#)) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on X ([Formerly Twitter](#)) | [Facebook](#)



High Peak
Borough Council



STAFFORDSHIRE
moorlands
DISTRICT COUNCIL
ACHIEVING • EXCELLENCE

