

Mucklow & Harris Ltd		Page 1
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model	
Return Period (years)	2
FEH Rainfall Version	2013
Site Location	GB 404500 337500 SK 04500 37500
Data Type	Point
Maximum Rainfall (mm/hr)	0
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
PIMP (%)	100
Add Flow / Climate Change (%)	0
Minimum Backdrop Height (m)	0.000
Maximum Backdrop Height (m)	0.000
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.323	4-8	0.224

Total Area Contributing (ha) = 0.547

Total Pipe Volume (m³) = 51.030

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	19.454	0.193	100.8	0.050	6.00	0.0	0.600	o	375	Pipe/Conduit	
1.001	23.215	0.341	68.1	0.135	0.00	0.0	0.600	o	375	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	6.18	110.800	0.050	0.0	0.0	0.0	1.80	199.3	0.0
1.001	0.00	6.36	110.607	0.185	0.0	0.0	0.0	2.20	242.8	0.0

Mucklow & Harris Ltd		Page 3
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

Manhole Schedules for Storm

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
10	112.825	2.025	Open Manhole	1350	1.000	110.800	375				
11	112.650	2.043	Open Manhole	1350	1.001	110.607	375	1.000	110.607	375	
12	112.250	2.419	Open Manhole	1800	2.000	109.831	825				
13	112.101	2.285	Open Manhole	1800	1.002	109.816	825	1.001	110.266	375	
								2.000	109.816	825	
14	112.300	2.538	Open Manhole	1800	1.003	109.762	825	1.002	109.762	825	
15	111.975	2.243	Open Manhole	1350	3.000	109.732	450				
FCC A	111.975	2.264	Open Manhole	3000	1.004	109.711	300	1.003	109.711	825	
								3.000	109.711	450	
headwall	111.000	1.338	Open Manhole	0		OUTFALL		1.004	109.662	300	

No coordinates have been specified, layout information cannot be produced.

Mucklow & Harris Ltd		Page 4
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

PIPELINE SCHEDULES for Storm

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	o	375	10	112.825	110.800	1.650	Open Manhole	1350
1.001	o	375	11	112.650	110.607	1.668	Open Manhole	1350
2.000	o	825	12	112.250	109.831	1.594	Open Manhole	1800
1.002	o	825	13	112.101	109.816	1.460	Open Manhole	1800
1.003	o	825	14	112.300	109.762	1.713	Open Manhole	1800
3.000	o	450	15	111.975	109.732	1.793	Open Manhole	1350
1.004	o	300	FCC A	111.975	109.711	1.964	Open Manhole	3000

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	19.454	100.8	11	112.650	110.607	1.668	Open Manhole	1350
1.001	23.215	68.1	13	112.101	110.266	1.460	Open Manhole	1800
2.000	8.887	592.5	13	112.101	109.816	1.460	Open Manhole	1800
1.002	37.639	697.0	14	112.300	109.762	1.713	Open Manhole	1800
1.003	35.390	693.9	FCC A	111.975	109.711	1.439	Open Manhole	3000
3.000	10.408	495.6	FCC A	111.975	109.711	1.814	Open Manhole	3000
1.004	12.345	251.9	headwall	111.000	109.662	1.038	Open Manhole	0

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.004	headwall	111.000	109.662	0.000	0	0

Mucklow & Harris Ltd		Page 5
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze Network 2019.1		
<u>Simulation Criteria for Storm</u> Volumetric Runoff Coeff 0.750 Additional Flow - % of Total Flow 0.000 Areal Reduction Factor 1.000 MADD Factor * 10m³/ha Storage 2.000 Hot Start (mins) 0 Inlet Coefficient 0.800 Hot Start Level (mm) 0 Flow per Person per Day (l/per/day) 0.000 Manhole Headloss Coeff (Global) 0.500 Run Time (mins) 60 Foul Sewage per hectare (l/s) 0.000 Output Interval (mins) 1 Number of Input Hydrographs 0 Number of Storage Structures 2 Number of Online Controls 1 Number of Time/Area Diagrams 0 Number of Offline Controls 0 Number of Real Time Controls 0 <u>Synthetic Rainfall Details</u> Rainfall Model FSR Profile Type Summer Return Period (years) 100 Cv (Summer) 0.750 Region England and Wales Cv (Winter) 0.840 M5-60 (mm) 19.000 Storm Duration (mins) 30 Ratio R 0.373		
©1982-2019 Innovyze		

Mucklow & Harris Ltd		Page 6
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

Online Controls for Storm

Hydro-Brake® Optimum Manhole: FCC A, DS/PN: 1.004, Volume (m³): 34.9

Unit Reference	MD-SHE-0295-5000-0950-5000
Design Head (m)	0.950
Design Flow (l/s)	50.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	295
Invert Level (m)	109.711
Minimum Outlet Pipe Diameter (mm)	375
Suggested Manhole Diameter (mm)	1800

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	0.950	50.0
Flush-Flo™	0.438	49.9
Kick-Flo®	0.753	44.7
Mean Flow over Head Range	-	39.7

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	9.1	1.200	55.9	3.000	87.2	7.000	131.8
0.200	30.3	1.400	60.3	3.500	94.0	7.500	136.4
0.300	48.5	1.600	64.3	4.000	100.3	8.000	140.8
0.400	49.8	1.800	68.1	4.500	106.3	8.500	145.0
0.500	49.7	2.000	71.6	5.000	111.9	9.000	149.1
0.600	48.7	2.200	75.0	5.500	117.2	9.500	153.1
0.800	46.0	2.400	78.2	6.000	122.3		
1.000	51.2	2.600	81.4	6.500	127.2		

Mucklow & Harris Ltd		Page 7
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

Storage Structures for Storm

Porous Car Park Manhole: 13, DS/PN: 1.002

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	6.0
Membrane Percolation (mm/hr)	1000	Length (m)	120.0
Max Percolation (l/s)	200.0	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	0
Porosity	0.30	Evaporation (mm/day)	0
Invert Level (m)	109.816	Cap Volume Depth (m)	0.350

Tank or Pond Manhole: 15, DS/PN: 3.000

Invert Level (m) 109.850

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	100.0	0.700	0.0	1.400	0.0	2.100	0.0
0.100	100.0	0.800	0.0	1.500	0.0	2.200	0.0
0.200	100.0	0.801	0.0	1.600	0.0	2.300	0.0
0.300	100.0	1.000	0.0	1.700	0.0	2.400	0.0
0.400	100.0	1.100	0.0	1.800	0.0	2.500	0.0
0.401	0.0	1.200	0.0	1.900	0.0		
0.600	0.0	1.300	0.0	2.000	0.0		

Mucklow & Harris Ltd

Page 8

Studio 313 Scott House

The Custard Factory, Gibb St...

Birmingham, B9 4AA

Fole Diary

CB COLLIER

Network A

Date 28/11/2022 08:36

File Storm A 28.11.22.MDX

Designed by Riaz Alam

Checked by

Innovyze

Network 2019.1

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1)

for Storm

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 2.000

Inlet Coefficient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Online Controls 1

Number of Offline Controls 0

Number of Storage Structures 2

Number of Time/Area Diagrams 0

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.000

Ratio R 0.373

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status ON

DVD Status ON

Inertia Status ON

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440

Return Period(s) (years) 1, 2, 30, 100

Climate Change (%) 0, 0, 0, 40

PN	US/MH	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	10 15	Winter	1	+0%					110.846
1.001	11 15	Winter	1	+0%					110.686
2.000	12 15	Winter	1	+0%					109.947
1.002	13 60	Winter	1	+0%					109.929
1.003	14 60	Winter	1	+0%					109.886
3.000	15 60	Winter	1	+0%	100/30 Winter				109.851
1.004	FCC A 60	Winter	1	+0%	100/15 Summer				109.850

PN	US/MH	Depth (m)	Volume (m³)	Flow / Cap. (l/s)	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	10	-0.329	0.000	0.04		6.0	OK	
1.001	11	-0.296	0.000	0.10		20.6	OK	
2.000	12	-0.709	0.000	0.05		15.9	OK	
1.002	13	-0.712	0.000	0.03		12.7	OK	
1.003	14	-0.701	0.000	0.03		14.4	OK	
3.000	15	-0.331	0.000	0.06		4.6	OK	

©1982-2019 Innovyze

Mucklow & Harris Ltd		Page 9
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

PN	US/MH Name	Surcharged		Flooded		Pipe		Status	Level Exceeded
		Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)			
1.004	FCC A	-0.161	0.000	0.29		16.5		OK	

Mucklow & Harris Ltd

Page 10

Studio 313 Scott House

The Custard Factory, Gibb St...

Birmingham, B9 4AA

Fole Diary

CB COLLIER

Network A

Date 28/11/2022 08:36

File Storm A 28.11.22.MDX

Designed by Riaz Alam

Checked by

Innovyze

Network 2019.1

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1)

for Storm

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 2.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Online Controls 1

Number of Offline Controls 0

Number of Storage Structures 2

Number of Time/Area Diagrams 0

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.000

Ratio R 0.373

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status ON

DVD Status ON

Inertia Status ON

Profile(s)

Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440

Return Period(s) (years) 1, 2, 30, 100

Climate Change (%) 0, 0, 0, 40

Summer and Winter

US/MH

PN

Name

Storm

Return Period

Climate Change

First (X) Surge

First (Y) Flood

First (Z) Overflow

Overflow Act.

Water Level (m)

1.000

10 15

Winter

2

+0%

110.852

1.001

11 15

Winter

2

+0%

110.697

2.000

12 15

Winter

2

+0%

109.965

1.002

13 60

Winter

2

+0%

109.952

1.003

14 60

Winter

2

+0%

109.909

3.000

15 60

Winter

2

+0%

100/30

Winter

109.871

1.004

FCC A 60

Winter

2

+0%

100/15

Summer

109.871

Surcharged

Flooded

Pipe

US/MH

PN

Name

Depth (m)

Volume (m³)

Flow / Cap.

Overflow (l/s)

Pipe Flow (l/s)

Status

Level Exceeded

1.000

10

-0.323

0.000

0.05

7.7

OK

1.001

11

-0.285

0.000

0.13

26.6

OK

2.000

12

-0.691

0.000

0.06

20.5

OK

1.002

13

-0.689

0.000

0.04

17.8

OK

1.003

14

-0.678

0.000

0.04

20.1

OK

3.000

15

-0.311

0.000

0.07

5.7

OK

©1982-2019 Innovyze

Mucklow & Harris Ltd		Page 11
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

		Surcharged	Flooded			Pipe		
PN	US/MH Name	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)	Status	Level Exceeded
1.004	FCC A	-0.140	0.000	0.37		21.0	OK	

Mucklow & Harris Ltd									Page 12
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A								
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by								
Innovyze	Network 2019.1								
30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm									
Simulation Criteria									
Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000						
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	2.000						
Hot Start Level (mm)	0	Inlet Coefficient	0.800						
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000						
Foul Sewage per hectare (l/s)	0.000								
Number of Input Hydrographs	0	Number of Storage Structures	2						
Number of Online Controls	1	Number of Time/Area Diagrams	0						
Number of Offline Controls	0	Number of Real Time Controls	0						
Synthetic Rainfall Details									
Rainfall Model	FSR	Ratio R	0.373						
Region England and Wales Cv (Summer)	0.750								
M5-60 (mm)	19.000	Cv (Winter)	0.840						
Margin for Flood Risk Warning (mm)			300.0						
Analysis Timestep	2.5 Second Increment (Extended)								
DTS Status			ON						
DVD Status			ON						
Inertia Status			ON						
Profile(s)			Summer and Winter						
Duration(s) (mins)	15, 30, 60, 120, 240, 360, 480, 960, 1440								
Return Period(s) (years)	1, 2, 30, 100								
Climate Change (%)	0, 0, 0, 40								
PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	10 15 Winter		30	+0%					110.875
1.001	11 15 Winter		30	+0%					110.744
2.000	12 30 Winter		30	+0%					110.041
1.002	13 30 Winter		30	+0%					110.037
1.003	14 60 Winter		30	+0%					109.999
3.000	15 60 Winter		30	+0%	100/30 Winter				109.974
1.004	FCC A 60 Winter		30	+0%	100/15 Summer				109.973
PN	US/MH Name	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status	Level Exceeded	
1.000	10	-0.300	0.000	0.09		14.6	OK		
1.001	11	-0.238	0.000	0.29		59.7	OK		
2.000	12	-0.615	0.000	0.10		31.5	OK		
1.002	13	-0.604	0.000	0.10		45.0	OK		
1.003	14	-0.588	0.000	0.10		46.2	OK		
3.000	15	-0.208	0.000	0.11		8.8	OK		

Mucklow & Harris Ltd		Page 13
Studio 313 Scott House The Custard Factory, Gibb St... Birmingham, B9 4AA	Fole Diary CB COLLIER Network A	
Date 28/11/2022 08:36 File Storm A 28.11.22.MDX	Designed by Riaz Alam Checked by	
Innovyze	Network 2019.1	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

		Surcharged	Flooded			Pipe		
PN	US/MH Name	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)	Status	Level Exceeded
1.004	FCC A	-0.038	0.000	0.75		42.4	OK	

