

Dealt with by: Environmental Health

Our Ref: SMD/2024/0024

Direct Dial: (01538) 395400

Your Ref:

Email:

Date: 3rd April 2024

MEMORANDUM: PLANNING CONSULTATION

LOCATION

**2 Charles Street
Cheadle**

PROPOSED DEVELOPMENT

**The Development of 2 Charles Street, ST10 1ED:
Conversion from Commercial Restaurant (Use Class E)
and Upper Floor Residential to Supported Living (Use
Class C2) to Establish 5 Supported Living Bedspaces
and 1 Overnight Bedspace, Along with the Construction
of a Rear Outbuilding and Landscaping Enhancements**

Potential Areas Of Environmental Concern.

1. Construction / conversion impacts (Condition)
2. Lighting (Condition)
3. Delivery (Condition Times)
4. Sound Insulation / Noise Breakout (Condition)

General Comments

The proposal to change the use from Class Use E (Restaurant) to C2 (Supported Living) for the proposed use does not appear significant from a noise impact perspective but the range of residential uses can be different. It would be recommended that noise breakout is considered during the development phase in order to future proof the site and ensure good neighbour relations. Noise transfer from room to room should also be given consideration in order to maintain good amenity for other occupiers of the home. The applicant emphasises noise management. A condition is advised below to take account of

Please note - The granting of planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of part III of the Environmental Protection Act 1990 be received.

Advisory - The developer should pay due regard for the need to be compliant/ adhere to Building regulations Approved Document E and BS8233:2014 Guidance on Sound Insulation and Noise Reduction for Buildings (special note should be made to Section 7.7.5 and Annex H). It would be advisable to appoint a buildings acoustics specialist to conduct a site specific assessment of the site to ensure this building is future proofed for all uses permitted under this permission.

Recommendation and Conditions

The Environmental Health department have no objections in principle subject to the following conditions being applied to any permission granted.

Construction & Demolition works: Time of operations

1. Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.
 - 08:00 - 18:00 hours (Monday to Friday);
 - 08:00 - 13:00 hours (Saturday)
 - No working is permitted on Sundays or Bank Holidays.In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: *To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.*

Construction & Demolition: Pollution Control

2.
 - I. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records should be retained for inspection by officers of the Local Planning Authority;
 - II. No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely affect adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

Reason: *To protect the amenities of the area during construction*

Unexpected Contamination

3. In the event that contamination is found at any time when carrying out the approved development it must be reported in writing immediately to the Local Planning Authority. Development should not commence further until an initial investigation and risk assessment has been completed in accordance with a scheme to be agreed by the Local Planning Authority to assess the nature and extent of any contamination on the site. If the initial site risk assessment indicates that potential risks exist to any identified receptors, development shall not commence until a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property, and the natural and historical environment has been prepared, and is subject to the approval in writing of the local planning authority.

Following completion of measures identified in the approved remediation scheme and prior to bringing the development into first use, a verification report that demonstrates the effectiveness of the remediation carried out must be produced, and is subject to the approval in writing of the Local Planning Authority.

Reason: *To ensure that the proposed development meets the requirements of the National Planning Policy Framework in that all potential risks to human health, controlled waters and wider environment are known and where necessary dealt with via remediation and or management of those risks.*

Lighting

4. The artificial lighting incorporated into this site in connection to this application shall not increase the pre-existing illuminance or cause glare at the adjoining light sensitive locations when the light (s) is (are) in operation. Details of all artificial lighting to be installed under this permission should be submitted to and approved by the Local Planning Authority prior to development commencing.

Reason: *To protect the local amenities of the local residents by reason of excess of illuminance*

Delivery Noise

5. There shall be no deliveries between the hours of 21.00 hours and 07.00 hours Monday to Saturday inclusive, and not between the hours of 21.00 hours and 10.00 hours on Sundays and Public or Bank Holidays.

Reason:- *To safeguard the amenity of neighbouring residential occupiers.*

Noise Attenuation Scheme

6. Before use of the development commences, a noise-mitigation scheme shall be submitted in writing and approved in writing by the local planning authority detailing measures that will be implemented to ensure that any noise associated with the development does not cause detriment to amenity or a nuisance, especially to those living and working in the vicinity. The scheme shall be compiled in compliance with BS8233:2014 Guidance on Sound Insulation and Noise Reduction for Buildings.

Reason: *To protect the amenity of the locality, especially for people living and/or working nearby*

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>
- Any approved foul drainage system should meet the British Standard 6297:2007+A1:2008: Code of practice for the design and installation of drainage fields for use in wastewater treatment <http://www.bsigroup.com>
- Any approved noise scheme and measurements should pay due regard to British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014 Methods for rating and assessing industrial or commercial sound, ProPG: Planning & Noise Professional Practice Guidance on Planning & Noise New Residential Development 2017 and/or the Building Regulations 2010 Document E or other appropriate guidance.

- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (Defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>
- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
 - The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
 - Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456)
- If required, contamination risk assessments shall be carried out in accordance with UK policy and with the procedural guidance relating to the contaminated land regime, and should be in accordance with Planning Policy Statement 23 and the CLR Report Series 1-12.
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an "appropriate person". In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site; the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Protection Department and agreed in principle prior to site investigation works being undertaken. The Environmental Protection Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,

Environmental Health