

From: [Jane Curley](#)
To: [Planning Comments \(SMDC\)](#)
Subject: FW: DOC/2022/0077 Condition 12 - post completion report
Date: 03 July 2024 17:15:30

Jane Curley Senior Planning Officer (Majors and Commercial)

Planning

High Peak Borough Council and Staffordshire Moorlands District Council Mob:

www.highpeak.gov.uk | Follow HPBC on [X \(Formerly Twitter\)](#) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on [X \(Formerly Twitter\)](#) | [Facebook](#)

From: Colgan, Denis <>
Sent: Tuesday, July 2, 2024 2:03 PM
To: Jane Curley <>
Subject: RE: DOC/2022/0077 Condition 12 - post completion report

Hello Jane,

Based on this latest submission and specifically section 4.2, the assessment is reporting compliance with the criteria levels of 55dBA daytime. It has assessed the external sound level as 54.4dBA which marginally complies with BS8233:2014 criteria levels.

This condition can be discharged.

Thank You,

Denis

Mr Denis Colgan
Specialist Pollution Officer
Environmental Health

High Peak Borough Council and Staffordshire Moorlands District Council

Tel:

www.highpeak.gov.uk | Follow HPBC on [X \(Formerly Twitter\)](#) | [Facebook](#)

www.staffsmoorlands.gov.uk | Follow SMDC on [X \(Formerly Twitter\)](#) | [Facebook](#)



High Peak Borough Council
working for our community

