

Dealt with by: Environmental Health

Our Ref: smd/2024/0357_0358

Direct Dial: (01538) 395400

Your Ref: as above

Email: EHealth.Consultation@highpeak.gov.uk

Date: 6th August 2024

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION	73 Quiet Woman St Edward Street Leek
PROPOSED DEVELOPMENT	(0357) Change of Use from Currently Vacant Public house to form 4 Holiday Lets and associated listing building consent. (0358) Listed Building Consent for Change of Use from Currently Vacant Public house to form 4 Holiday Lets and associated listing building consent.

Potential Areas Of Environmental Concern.

1. Noise/ Demolition Impacts (Condition)
2. Asbestos (advisory)
3. Fire Safety (Building Regulations & Staffordshire Fire and Rescue)
4. Sound Insulation (Building regulations and advisory)

General Comment as per smd/2020/0689 and 0690

Asbestos: Any redundant on site that may well have asbestos containing materials (ACM) in their fabric (e.g. asbestos roof) To ensure no future asbestos contamination, as a result of demolition a "Demolition or refurbishment asbestos survey" and risk assessment should be carried out prior to the demolition of these buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>. This is included as an advisory.

Nuisance: The proposed development is close to existing properties so care needs to be taken during construction / demolition phase to ensure site related activities do not cause unreasonably disruption to the neighbour's enjoyment of their properties.

Fire Safety: Fire safety is subject to Building Regulations Document B. Consultation might also be made to Staffordshire Fire and Rescue.

Sound Insulation: As the rooms are being created under a material change of use then compliance with Approved Document E: Section 6 would be required. It would also be

advisable to consult BS8233:2014 Guidance on sound insulation and noise reduction for buildings.

Recommendation and Conditions

The Environmental Health Department have no objection subject to the following conditions being applied to any permission granted.

1. Construction & Demolition Works: Time of operations

Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.

- 08:00 - 18:00 hours (Monday to Friday);
- 08:00 - 13:00 hours (Saturday)
- No working is permitted on Sundays or Bank Holidays.

In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours.

2. Construction & Demolition: Construction Method Statement

- I. During construction/demolition phases amplified music and/or radios shall not be audible beyond the site boundary;
- II. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records should be retained for inspection by officers of the Local Planning Authority;
- III. No activity hereby permitted shall cause dust to be emitted beyond the site boundary so as to adversely affect adjacent residential properties and/or other sensitive uses and/or the local environment. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These should be made available for inspection when required by officers of the Local Planning Authority

Reason: *To protect the amenities of the area from dust*

Advisory Note/ Informative:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>
- The lighting scheme should comply with the Institution of Lighting Professionals Guidance Note for the reduction of obtrusive light 2011(or later versions). It should be designed so that it is the minimum needed for security and operational processes and be installed to minimise potential pollution caused by glare and spillage.

Illuminated area m ²	Zone E1	Zone E2	Zone E3	Zone E4
Up to 10.00	100	600	800	1000
Over 10.00	n/a	300	600	600

Environmental Zones			
Zone	Surrounding	Lighting Environment	Examples
E0	Protected	Dark	UNESCO Starlight Reserves, IDA Dark Sky Parks
E1	Natural	Intrinsically dark	National Parks, Areas of Outstanding Natural Beauty etc.
E2	Rural	Low district brightness	Village or relatively dark outer suburban locations
E3	Suburban	Medium district brightness	Small town centres or suburban locations
E4	Urban	High district brightness	Town/city centres with high levels of night-time activity

The guidance advises that, where an area to be lit lies on the boundary of two zones or can be observed from another zone, the limits used should be those applicable to the most rigorous zone.

- Any approved noise scheme and measurements should pay due regard to the Professional Guidance on Planning and Noise (ProPG), British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014+A1:2019 Methods for rating and assessing industrial or commercial sound and/or the Building Regulations 2010 Document E or other appropriate guidance
- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.

- The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils
<http://www.london.gov.uk/sites/default/files/BPGcontrolofdustandemissions.pdf>
- Building Research Establishment Guidance Document 'Control of Dust from Construction and Demolition Activities' (BR456)
- In accordance the Site Waste Management Plans Regulations 2008 any construction project with an estimated cost greater than £300,000 must, before work begins, prepare a Site Waste Management Plan in accordance with the requirement of these regulations.
- If required, contamination risk assessments shall be carried out in accordance with UK policy the Land contamination risk management framework (LCRM), published by the Environment Agency
<https://www.gov.uk/government/publications/land-contamination-risk-management-lcrm>
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an "appropriate person". In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site, the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Health Department and agreed in principle prior to site investigation works being undertaken. The Environmental Health Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,



Environmental Health