STAFFORDSHIRE moorlands DISTRICT COUNCIL

ACHIEVING · EXCELLENCE

Mr Patrick Redmond
CTD Architects
Clerk Bank House Clerk Bank
Leek
Staffordshire Moorlands
ST13 5HE

Mr Telford
Ferneylea Farm Foxt Road
Foxt
Staffordshire
ST10 2HJ

Application no: SMD/2023/0301

Determined on: 2nd October 2024

Town and Country Planning Act 1990
Town and Country Planning (Development Management Procedure) (England) Order 2015 (as Amended)

FULL PERMISSION FOR DEVELOPMENT

This permission does not carry any approval or consent which may be required under any enactment, bylaw, order or regulation (e.g. in relation to Building Regulations or the Diversion of Footpaths etc) other than Section 57 of the Town and Country Planning Act, 1990.

Location of Development:
Ferneylea Farm Foxt Road Foxt Staffordshire ST10 2HJ

Description of Development:
Erection of replacement dwelling along with conversion of agricultural shippon to additional living accommodation, and installation of ground mounted solar panel array

In pursuance of their power under the above mentioned Act, Staffordshire Moorlands District Council Planning Authority, **HEREBY GRANTS PLANNING PERMISSION** for the development described above subject to the following condition(s):

1. The development hereby permitted must be begun not later than three years from the date of this permission.
Reason: Required to be imposed pursuant to Section 91 of the Town and Country Planning Act 1990 as amended by Section 51 of the Planning and Compulsory Purchase Act 2004.

2. Unless explicitly required by condition within this consent, the development hereby permitted shall be carried out in complete accordance with the proposals as detailed on drawings:
2218 AL01 A Site Location Plan received by the Local Planning Authority on 24th July 2023

2218 AL 110 Perspective views – rendered

2218 AL 106 site plan as proposed
2218 AL 108 Perspective views as proposed
2218 AL 112 General Arrangements Section 1
2218 AL 109 indicative drainage plan
2218 AL 107 General Arrangements drawing as proposed

received by the Local Planning Authority on 13th February 2024

Reason: For the avoidance of doubt and to clarify which plans are relevant to the consent.

3. The development shall be carried out in accordance with the materials specified on the approved plans unless otherwise agreed in writing by the Local Planning Authority.

Reason: To ensure that the external appearance of the building is satisfactory.

4. All rooflights hereby permitted shall be conservation style rooflights set as flush as practicable within the roof slope.

Reason: To ensure the development preserves the character and appearance of the area

5. No demolition or site clearance shall take place until drainage plans for the disposal of foul and surface water flows have been submitted to and approved in writing by the Local Planning Authority, and the scheme shall be implemented in accordance with the approved details before the development is first brought into use.

Reason: To ensure that the development is provided with a satisfactory means of drainage as well as to prevent or to avoid exacerbating any flooding issues and to minimise the risk of pollution.

6. No demolition or site clearance shall take place until:
a) a scheme of intrusive investigations has been carried out on site to establish the risks posed to the development by past shallow coal mining activity; and
b) any remediation works and/or mitigation measures to address land instability arising from coal mining legacy, as may be necessary, have been implemented on site in full in order to ensure that the site is made safe and stable for the development proposed.
The intrusive site investigations and remedial works shall be carried out in accordance with authoritative UK guidance.

Reason: The undertaking of intrusive site investigations, prior to the commencement of development, is considered to be necessary to ensure that adequate information pertaining to ground conditions and coal mining legacy is available to enable appropriate remedial and mitigatory measures to be identified and carried out before building works commence on site.

This is in order to ensure the safety and stability of the development, in accordance with paragraphs 183 and 184 of the National Planning Policy Framework.

7. Prior to the occupation of the development, or it being taken into beneficial use, a signed statement or declaration prepared by a suitably competent person confirming that the site is, or has been made, safe and stable for the approved development shall be submitted to the Local Planning Authority and approved in writing. This document shall confirm the methods and findings of the intrusive site investigations and the completion of any remedial works and/or mitigation necessary to address the risks posed by past coal mining activity.

Reason: The undertaking of intrusive site investigations, prior to the commencement of development, is considered to be necessary to ensure that adequate information pertaining to ground conditions and coal mining legacy is available to enable appropriate remedial and mitigatory measures to be identified and carried out before building works commence on site. This is in order to ensure the safety and stability of the development, in accordance with paragraphs 183 and 184 of the National Planning Policy Framework.

8. Unless prior permission has been obtained in writing from the Local Planning Authority, all noisy activities shall be restricted to the following times of operations.
• 08:00 - 18:00 hours (Monday to Friday);
• 08:00 - 13:00 hours (Saturday)
• No working is permitted on Sundays or Bank Holidays.
In this instance a noisy activity is defined as any activity (for instance, but not restricted to, building construction/demolition operations, refurbishing and landscaping) which generates noise that is audible at the site boundary.

Reason: To avoid the risk of disturbance to neighbouring dwellings from noise during unsocial hours

9. I. Any waste material associated with the demolition or construction shall not be burnt on site but shall be kept securely for removal to prevent escape into the environment. All waste transfer records shall be retained for inspection by officers of the Local Planning Authority;
II. No activity hereby permitted shall cause dust to be emitted beyond the site boundary. In the event dust is caused to escape the site boundary the activity shall be stopped until sufficient dust suppression has been undertaken to prevent further escape. There shall always be the appropriate means and sufficient water resources on site for dust suppression. These shall be made available for inspection when required by officers of the Local Planning Authority;

Reason: To protect the amenities of the area during construction

10. In the event that contamination is found at any time when carrying out the approved development it must be reported in writing immediately to the Local Planning Authority.

Development shall not continue until an initial investigation and risk assessment has been completed in accordance with a scheme to be agreed in writing by the Local Planning Authority to assess the nature and extent of any contamination on the site. If the initial site risk assessment indicates that potential risks exists to any identified receptors, development shall not recommence until a detailed remediation scheme to bring the site to a condition suitable for the intended use by removing unacceptable risks to human health, buildings and other property, and the natural and historical environment has been submitted to and approved in writing by the local planning authority. Following completion of measures identified in the approved remediation scheme and prior to bringing the development into first use, a verification report that demonstrates the effectiveness of the approved remediation shall be submitted to and approved in writing by the Local Planning Authority.

11. Any external lighting which is to be incorporated into this site in connection to this application shall not increase the pre-existing illuminance at the adjoining light sensitive locations when the light(s) is(are) in operation. Details of all external lighting to be installed at the site shall be submitted to and approved in writing by the Local Planning Authority prior to their installation and the works shall be carried out in full accordance with the agreed details.

Reason: To protect the local amenities of the local residents by reason of excess of Illuminance

12. The development shall take place incorporating the mitigation measures and in accordance with the working methods all as detailed at within the Impacts and Recommendations section in the submitted species survey by Mark Weston dated September 2022 or as stipulated by any Natural England European Protected Species (EPS) Licence in which case the work shall be implemented in accordance with the EPS Licence and in either event shall be implemented prior to the first occupation of the development and retained as approved for the lifetime of the development.

Reason: to safeguard the population of European Protected Species.

13. No building or use hereby permitted shall be occupied or use commenced until full details of Soft Landscaping has been submitted to and approved in writing by the Local Planning Authority. This will be a detailed planting plan and specification of works indicating soil depths, plant species, numbers, densities, locations inter relationship of plants, stock size and type, grass, and planting methods including construction techniques for pits in hard surfacing and root barriers. All planting, seeding or turfing comprised in the approved details of landscaping shall be carried out in the first planting and seeding seasons following the occupation of the buildings or the completion of the development whichever is the sooner; and any trees or plants which within a period of 5 years from the completion of the landscaping scheme die, are removed or become seriously damaged or diseased shall be replaced in the next planting season with others of similar size and species unless the Local Planning Authority gives written consent to any variation.

Reason: To ensure a high quality planting scheme is provided in the interests of visual amenity which contributes positively to local character and enhances bio diversity.

Informative

1.The Local Planning Authority (LPA), in reaching this decision, has followed the guidance in paragraph 38 of the National Planning Policy Framework. The Framework advises that the LPA should work proactively with applicants to secure developments that improve the economic, social and environmental conditions of the area.

X B.J. Haywood

Signed by: Ben Haywood

On behalf of Staffordshire Moorlands District Council

Moorlands House, Stockwell Street, Leek, Staffordshire Moorlands, ST13 6HQ.
www.staffsmoorlands.gov.uk Tel: 0345 605 3010
All correspondence to Staffordshire Moorlands District Council, P O Box 136, Buxton, SK17 1AQ.

disability confident EMPLOYER

STAFFORDSHIRE moorlands DISTRICT COUNCIL

ACHIEVING · EXCELLENCE

NOTES

1. Approval under the Building Regulations may also be required. Advice in this respect can be obtained by contacting DBCP Limited, Web: dbcp.co.uk; Email: info@dbcp.co.uk ; Tel:0333 880 2000.

1. Where a vehicle is often driven across a grass verge or kerbed footway to and from premises adjoining a highway, the occupier of the premises may, be required to pay the cost of construction of a crossing, and/or may be required to comply with conditions, imposed by the Authority. You should contact the Highway Authority at Staffordshire County Council.

2. This consent is granted subject to conditions and it is the owner(s) and the person(s) responsible for the implementation of the development who will be fully responsible for their compliance throughout the development and beyond. An application will need to be made to discharge conditions and a fee is payable with the application. For more details please refer to our web site: www.staffsmoorlands.gov.uk If there is a condition that requires work to be carried out or details to be approved prior to the commencement of the development this is called a "condition precedent". The following should be noted with regards to conditions precedent:
   (a) If a condition precedent is not complied with, the whole of the development will be unauthorised and you may be liable to enforcement action.
   (b) Where a condition precedent is breached and the development is unauthorised, the only way to rectify the development is the submission of a new application.

3. Other conditions on this permission must also be complied with. Failure to comply with any condition may render the owner(s) and the person(s) responsible for the implementation of the development liable to enforcement action.

4. The permission is granted in strict accordance with the approved plans. It should be noted however that:
   (a) Any variation from the approved plans following commencement of the development irrespective of the degree of variation will constitute unauthorised development and may be liable to enforcement action.
   (b) Variation to the approved plans will require the submission of a new planning application.

5. If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

6. If the decision to refuse planning permission is for a householder application, and you want to appeal against your local planning authority's decision then you must do so within 12 weeks

of the date of this notice.

7. If this is a decision to refuse planning permission for a minor commercial application, and you want to appeal against your local planning authority's decision then you must do so within 12 weeks of the date of this notice.

8. If this is a decision to refuse express consent for the display of an advertisement, if you want to appeal against your local planning authority's decision then you must do so within 8 weeks of the date of receipt of this notice.

9. If you want to appeal against your local planning authority's decision for any other type of development, including listed building consents then you must do so within 6 months of the date of this notice Appeals must be made using a form which you can get from the Secretary of State at Temple Quay House, 2 The Square, Temple Quay, Bristol BS1 6PN (Tel: 0303 444 5000) or online at https://acp.planninginspectorate.gov.uk

10. The Secretary of State can allow a longer period for giving notice of an appeal, but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal. The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

11. If either the local planning authority or the Secretary of State refuses permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted. In these circumstances, the owner may serve a purchase notice on the Council (District Council, London Borough Council or Common Council of the City of London) in whose area the land is situated. This notice will require the Council to purchase his interest in the land in accordance with the provisions of Part VI of the Town and Country Planning Act 1990.

12. Domestic sprinklers
    Fire sprinklers operate automatically even if you are not at home releasing water directly over the source of the fire and sounding the alarm, they are unobtrusive and easy to install.
    Sprinklers are NOT expensive; normally costing around 1-2% of the cost of construction of a new building. The use of sprinklers will usually allow design freedoms as well, which can reduce construction costs and improve usability and design freedoms of the building.
    The chance of an accidental discharge is 16,000,000:1
    If you would like further advice please contact Staffordshire Fire and Rescue Service (www.staffordshirefire.gov.uk)

13. Working smoke alarms correctly positioned in your home can save your life.

The Fire Service recommends you have smoke alarms on every floor of your home, including in each bedroom, and make sure you test your smoke alarms at least once a month. Although the application of approved guidance and enforcement of regulations will give buildings the legally required baseline of fire protection, the Fire Service's viewpoint is many of these fall short of what we would consider adequate. This is why we campaign for the inclusion of sprinklers.