

Subject: Comment Received from Public Access
Date: 06 November 2024 15:45:17

Application Reference No. : SMD/2024/0441
Site Address: 29 King Street Leek Staffordshire ST13 5NW Leek
Comments by: the trustees Leek and Moorlands Historic Buildings Trust
From:

Broad Street
Leek
Leek

Submission: Neither
Comments: 29 King Street Leek

Proposed replacement front windows

SMD/2024/0441

COMMENT on the Planning Application from the Leek and Moorlands Historic Buildings Trust

The proposed design is inappropriate, having regard to the original form of fenestration for King Street. The windows should be of the 8 over 8 pane type of sliding sashes with concealed boxes.

If still present, the neighbouring no.31 first floor window design would be ideal.

The Trust can if required provide advice to the applicant on a suitable joinery contractor and possibly aid the applicant with Council funded grant assistance.

Also: if the Application is required because of the Council having made an article 4 direction, a prescribed fee payment may not have been necessary.

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.staffsmoorlands.gov.uk/YourData>