

From: EHealth Consultation
Sent: 20 November 2024 14:10
To: Chris Johnston
Subject: RE: App ref DOC/2024/0068 the Old Bowling Green

Hello Chris,

Environmental health recommend discharge of condition 12 subject to all outlined noise mitigation and sound insulation being installed –

1. The installation of a 1.8m acoustic barrier as proposed in section 8.4 and fig. 12,
2. Plot specific build specification listed in sections 8 and 9 being completed in full,
3. All sound insulation installed should also be compliant with Building regulations 201: approved Document O – Overheating.

Thanks

Denis,

Mr Denis Colgan
Specialist Pollution Officer
Environmental Health

High Peak Borough Council and Staffordshire Moorlands District Council

www.highpeak.gov.uk | Follow HPBC on [X \(Formerly Twitter\)](#) | [Facebook](#)

www.staffs Moorlands.gov.uk | Follow SMDC on [X \(Formerly Twitter\)](#) | [Facebook](#)

