

Severn Trent Water Consultation Response:

Thank you for the additional information below.

Given the proposal for surface water is discharge to a private asset before outfalling to the river, we would have no comment to make and advise this is discussed with the LLFA.

We have no objections to the foul sewage proposal: The submitted 'Strategic Drainage and SUDs Maintenance Plan' (drawing ref: KT24-028-100 Rev: /) shows all foul sewage is proposed to discharge to the public combined sewer at manhole 7601.

Based upon these proposals I can confirm we have no objections to the discharge of the drainage related condition.

Please note for the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website

(<https://url6.mailanyone.net/scanner?m=1tch4g-00000009WVj-3kHI&d=4%7Cmail%2F90%2F1738053000%2F1tch4g-00000009WVj-3kHI%7Cin6a%7C57e1b682%7C10609168%7C13286642%7C679896EE7204904D8103D11B10B80D16&o=a.wwwetwtwsku.oc.r&s=NXgeJwHjQ5pLAv6rH45a47h6QHo>) or by contact our Development Services Team (Tel: 0800 707 6600).

I trust you find the above in order, however, if you have any further enquiries then please do not hesitate to contact us.

Kindest regards,

Rhiannon