
From:
Sent: 20 May 2025 10:31
To: Planning Comments (SMDC)
Subject: FW: App ref DOC/2025/0029 Bath House Basford Hall

Categories:

-----Original Message-----

From:
Sent: 20 May 2025 10:30
To:
Subject: App ref DOC/2025/0029 Bath House Basford Hall

Hello ,

Discharge of conditions 7 and 8 in relation to SMD/2024/0427

Condition 7 - Lighting appears relatively low level and based on what is provided unlikely to adversely impact amenity. Recommend discharge.

Condition 8 - Plant noise. There is no noise advice provided. There is a plant building proposed and details of the plant proposed but no noise specifications or building detail. Will all the plant be installed inside a suitably designed building to provide noise attenuation. Insufficient information provided at this stage to discharge.

Thank You,

Specialist Pollution Officer
Environmental Health

High Peak Borough Council and Staffordshire Moorlands District Council

www.highpeak.gov.uk
www.staffsmoorlands.gov.uk

Do you really need to print out this Email? Be green - keep it on the screen.

This email is intended for the addressee(s) only and may contain sensitive, privileged or confidential information that could be protectively marked. If you are not the addressee please do not use the information in any way. If you have received this email in error please notify the sender immediately and delete it from your system. Thank you.

The Council may be required to disclose this email or any responses to it under the Freedom of Information Act 2000. The way in which we handle personal information is set out in our privacy notice and is available at <https://www.highpeak.gov.uk/YourData>
