

# Chartered Building Surveying & Property Consultancy



## Lighting Assessment Statement

For

Listed Building Consent

At

**Westwood College  
Westwood Park  
Leek  
ST13 8NP**



July 2025

“Delivering Aspirations”



**CONTENTS**

**1.0    Introduction..... 3**

**2.0    Proposed Works ..... 3**

## **Introduction**

This lighting assessment has been produced following proposals to install emergency lighting to external areas located on the building in order to comply with current regulations / standard surrounding emergency lighting provision.

The works form part of a larger scheme aimed at improving the over all fire safety of the Westwood College school buildings.

### **1.0 Proposed Works**

Installation of LED external and internal emergency light fittings.

Refer to drawings and 'Relux' calculations for detailed information.

All proposed externally mounted light fittings shall be non-maintained emergency fittings. The fittings will only illuminate in emergency scenarios leading to the loss of power within the school. The illumination from the fittings is to enable the safe exit from the building in an emergency as per BS 5266 and will not function as general use lighting.

The emergency lighting will not have set operational times. The emergency lighting can be activated at any time of the day following a loss of power.