

Dealt with by: Environmental Health

Our Ref: smd/2025/0367

Direct Dial: [REDACTED]

[REDACTED] e

Email: [REDACTED]

Date: 16th October 2025

MEMORANDUM: PLANNING CONSULTATION
--

LOCATION

Broadhurst Farm Leek Road

Waterhouses

PROPOSED DEVELOPMENT

Change of use of three holiday cottages from holiday accommodation to open-market houses

Potential Areas of Environmental Concern -

1. Noise transfer between units (Building Regulations to be confirmed)
2. Farm Noise (Further information required)
3. Farm Odour (Further information required)

General Comments

Sound Insulation between units: Please consult Building Control to check if Building Regulation Document E applies to this proposed change of use. This building regulation was introduced in approx. 2003-2004, it is not clear what year these units were built and if they have been built to a modern sound insulation specification. If the regulations do not apply and we have no certainty as to the level of sound insulation between the units then we would advise sound testing is undertaken to determine if the party wall meet the required resistance to sound standards.

Farm Noise: The proposed site appears to be adjacent to a working farm and so there is potential for noise disturbance if suitable sound insulation is not installed. We would advise a site specific sound insulation scheme is submitted with the application so we can properly consider if the site is suitable for third party occupation. This would include the outside living areas. The current short term holiday let controlled by the farm would have meant amenity would have been protected but these units may be sold to third party occupiers.

Farm Odour: No advice is provided on any close by animal housing or manure/slurry storage which can generate smells likely to impact residential amenity. As mentioned these residential are likely to be occupied by people not associated with the farm and so their amenity could be compromised and complaint against the farm might be caused.

Recommendation – Environmental Health recommend that further advice is provided to address internal noise transfer, farm noise and odour.

Advisory:

Please be aware that the responsibility for safe development and secure occupancy of the site rests with the developer.

- A Demolition or refurbishment asbestos survey and risk assessment should be carried out prior to the demolition of the existing buildings. The enforcing authority for this type of work is the Health and Safety Executive (HSE) and it is recommended that you contact them directly to discuss their requirements: <http://www.hse.gov.uk/>
- Any approved foul drainage system should meet the British Standard 6297:2007+A1:2008: Code of practice for the design and installation of drainage fields for use in wastewater treatment <http://www.bsigroup.com>
- Any approved noise scheme and measurements should pay due regard to British Standard BS8233: Sound insulation and noise reduction for buildings (Code of Practice), BS4142:2014+A1:2019 Methods for rating and assessing industrial or commercial sound and/or the Building Regulations 2010 Document E or other appropriate guidance.
- Advice on controlling flies and light can be found in: Statutory Nuisance from Insects and Artificial Light (defra 2005) available as a free download <http://archive.defra.gov.uk/environment/quality/local/legislation/cnea/documents/statnuisance.pdf>
- The lighting scheme should comply with the Institution of Lighting Professionals Guidance Note for the reduction of obtrusive light 2011(or later versions). It should be designed so that it is the minimum needed for security and operational processes and be installed to minimise potential pollution caused by glare and spillage.

Illuminated area m ²	Zone E1	Zone E2	Zone E3	Zone E4
Up to 10.00	100	600	800	1000
Over 10.00	n/a	300	600	600

Environmental Zones			
Zone	Surrounding	Lighting Environment	Examples
E0	Protected	Dark	UNESCO Starlight Reserves, IDA Dark Sky Parks
E1	Natural	Intrinsically dark	National Parks, Areas of Outstanding Natural Beauty etc.
E2	Rural	Low district brightness	Village or relatively dark outer suburban locations
E3	Suburban	Medium district brightness	Small town centres or suburban locations
E4	Urban	High district brightness	Town/city centres with high levels of night-time activity

The guidance advises that, where an area to be lit lies on the boundary of two zones or can be observed from another zone, the limits used should be those applicable to the most rigorous zone.

- During any demolition and construction activities (including landscaping) the contractor shall take all reasonable steps to prevent dust formation and prevent any dust formed from leaving the site boundary.
- The control of dust and emissions from construction and demolition Best Practice Guidance, produced by the greater London councils <https://www.london.gov.uk/programmes-strategies/planning/implementing-london-plan/london-plan-guidance-and-spgs/control-dust-and-emissions>
- If required, Contamination risk assessments shall be carried out in accordance with UK policy the Land contamination risk management framework (LCRM), published by the Environment Agency <https://www.gov.uk/government/publications/land-contamination-risk-management-lcrm>
 - Submission of reports should also be made to the Environment Agency for comment with regard to their remit to protect ground and surface waters from pollution and their obligations relating to contaminated land.
 - The Local Planning Authority will determine the acceptability of reports on the basis of the information made available to it. Please be aware that should a risk of harm from contamination remain post development, where the applicant had prior knowledge of the contamination, the applicant is likely to be liable under Part II (a) of the Environmental Protection Act 1990 and as such become an “appropriate person”. In this event the applicant will be lawfully responsible to remove the risk posed by the contamination.
 - Equally if during any site works a pathway for any contaminant on site is created and humans, waters, property or ecological systems are exposed to this, the applicant or those acting on behalf of the applicant will be liable under part II (a) of the Environmental Protection Act 1990 if the risks are not adequately addressed during the site redevelopment.
 - During investigation and remediation works the applicant and those acting on behalf of the applicant must ensure that site workers, public property and the environment are protected against noise, dust, odour and fumes
 - The applicant is advised that should there be a requirement as part of the Remediation Strategy to treat, reuse or remove contaminated material on the site, the Environment Agency must be consulted, as these activities may need to be licensed or permitted. Contaminated materials identified for removal off site must be disposed of in an appropriately licensed landfill site.
 - Staffordshire Moorlands District Council is keen to liaise with all stakeholders involved in this application. As such, we recommend that a proposed scope of works is forwarded to the Environmental Protection Department and agreed in principle prior to site investigation works being undertaken. The Environmental Protection Department is also prepared to review draft copies of reports prior to final submission to the Planning Department in order to ensure that works undertaken are sufficient to discharge the contaminated land conditions.

Regards,
Environmental Health