

[REDACTED]

Sent: 14 January 2026 10:52

[REDACTED]

Subject: FW: DOC/2025/0070 Old Police Station
Attachments: verification report.pdf; smd 2023 0368 pp.pdf; RE: Blythe Bridge App ref
DOC/2024/0087

[REDACTED]

Hi Lisa,

Re: Condition 10 (c)

Apologies for the delay but I was assuming more information was due to follow from the applicant.

The attached document is sufficient to demonstrate that the required gas verification has been installed correctly.

However, the remediation also required a soil cover layer to be installed etc. Validation that this has been undertaken in accordance with the remediation strategy also needs to be submitted to achieve full discharge of Condition 15 (c) (last communication attached).

Recommendation.

Full discharge of 15 c not yet recommended

Thanks

Dan

[REDACTED]



