ST. EDWARDS ENERGY SURVEYS LTD.

AIRTIGHTNESS TEST REPORT

RESULTS OF THE ENVELOPE
AIRTIGHTNESS TEST CARRIED OUT ON:-
LAKESIDE, REACLIFFE ROAD, RUDYARD, LEEK,
STAFFORDSHIRE, ST13 8RS.

Test reference No. 232 10
Dated 30 July, 2010.

Carried out for:- Mr. J. Shaw, Lakeside, Reacliffe Road, Rudyard, Leek, Staffordshire, ST13 8RS.

Carried out by:- St. Edwards Energy Surveys Ltd.
11, Wall Lane Terrace
Cheddleton
Leek
Staffordshire
ST13 7ED
Tel. 01538 361800 e-mail plamb737@hotmail.com

C.W. Lamb BINDT Registration No. 0192

DESIGN AIR PERMEABILITY:- 10.0 $m^3/(h.m^2)$@50Pa

TEST RESULT:- 5.13 $m^3/(h.m^2)$@50Pa

This dwelling passes the pressure test.