


PROPOSED CANOPY DETAIL ELEVATION 1:20



PROPOSED CANOPY DETAIL PLAN 1:20

150x75mm RAFTERS AT 550mm CENTRES AS NOTED ON ROOF PLAN

CODE 5 LEAD FLASHING WITH CAVITY TRAY DPC TO BE INSTALLED AT ABUTMENT OF NEW CANOPY ROOF AND EXISTING MASONRY

UNLESS OTHERWISE NOTED, ALL TIMBER TO BE PRESSURE TREATED SW C16, PLANED ALL ROUND TO RECEIVE COLOURED STAIN FINISH. MAIN FRAME TO BE JOINTED IN ACCORDANCE WITH THE SE'S DETAILS WITH ALL FIXINGS / BOLTS RECESSED AND PELLETED

NATURAL SLATES TO MATCH EXISTING MAIN ROOF ONTO 50x25mm TANNALISED SLATE BATTENS SET AT CENTRES TO SUIT LAP OF 100mm MINIMUM - SLATE BATTENS FIXED THROUGH TYPE 1F BITUMEN

REINFORCED SARKING FELT (OR SIMILAR APPROVED) THROUGH TO 25mm TANNALISED SW T&G BOARDED SUBSTRATE FIXED INTO RAFTERS.

TANNALISED SW T&G BOARDING TO RECEIVE DECORATIVE PAINT FINISH TO UNDERSIDE IN ACCORDANCE WITH THE SPECIFICATION BLACK 1/2 ROUND CAST IRON GUTTERING TO


ROUND C.I. DOWNPIPE MAIN POSTS AND TIES TO BE 150mm PAR POSTS TO HAVE 20x20mm CHAMFERED CORNERS

NEW RWP'S TO BE CONNECTED TO EXISTING DRAINAGE SYSTEM. M.C. TO MAKE ALL ALLOWANCES

NEW COPING TO TOP OF NEW RETAINING WALL CONSTRUCTION, TO BE MARSHALLS HERITAGE RIVEN RANGE, 'WEATHERED YORKSTONE', 38mm THICK, SUPPLIED IN 600mm LENGTHS. NOTE COPING EITHER SIDE OF POST WITH CUT-OUT FOR POST. ALLOW RECESS

NEW SOLID BRICKWORK RETAINING POST WITH CAVITY FILL REINFORCED CONCRETE. NOTE STARTER BARS TO RUN THROUGH TO FOUNDATION BELOW.

DRAWINGS.



KITCHEN EXTENSION SECTION 1:20

Copyright in this drawing remains with the architect. Do not scale from this drawing. Work to figured dimensions. Check all dimensions on site. In case of any discrepancy, refer query to the architect.

A	Prop' smoking a	canopy r	emoved	from app	D. CK	05.03.15
Rev	Rev Description					Date
	FOR	PLAN	NING C	ONSER	NT	
26 : em <u>ww</u>	RE DESIGN (UK) LIMITED Shaw Road Heaton Moo ail <u>architects@core-desi</u> w.core-design.net phone 0161 443 4000 fa	g <u>n.net</u> websi	te		C O D E S	R E ign
THE KNOT INN, Station Road, Rushton Spencer, Cheshire, SK11 0QU for Punch Taverns EXTENSION/CANOPY DETAILS AS PROPOSED						
DRAWN		DATE	Dec 20	14 DRAWIN	IG NO.	
SCALE	1:20 @ A1	REV.	А	- 140	098-30)5